



WATER DEPARTMENT JUNE 2015 MONTHLY REPORT

<u>Water Supplied this month</u>	10,393,300 gallons
<u>Average Daily Water Supplied</u>	346,443 gallons
<u>Water produced Y.T.D</u>	43,578,400 gallons

Water and Sewer Inspections

37 Harlequin Loop
502 S. Main St. – water only
12 Champions Dr.
147 Champions Dr.
139 Champions Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

502 S. Main St. – 1 meter/ 1 mxu
37 Harlequin Loop – 2 meters/ 1 mxu
31 Champions Dr. – 2 meters/ 1 mxu
12 Champions Dr. – 2 meter/1 mxu
147 Champions Dr. – 2 meters/1 mxu
3 Harlequin Loop – 2 meters/ 1 mxu
139 Champions Dr. – 2 meters/ 1 mxu
61 Whistling duck Dr. 1 meter – replace bad meter

Final Readings

33 Whistling duck Dr.

C.O. Inspections

3 Harlequin Loop

Meters removed : 3

127 N. Main St.
102 N. Cannon St.
55 Church St.

Service Calls : 17

Shut-offs : 5

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Turned in report for public works time spent at phase 3.
6. Meetings with Town Manger.
7. Did various Miss Utility locate tickets.
8. Repaired pin hole at pressure gauge at well 6.
9. Mowed grass at well 6, H.S. water tower, and H.S. lift station.
10. Replaced more faulty meter cables.
11. Sprayed weeds at wells, water tower, and at WWTP.
12. Flushed and tested flow on new fire hydrants on Walnut St.
13. Painted new hydrants the correct color, according to flow chart.
14. Had meeting with Jean from DRWA.
15. Attended Cross connection workshop at DRWA.
16. Recertified my ASSE backflow tester's license.
17. Helped Jeff and Rick with manhole at Oak and N. Cannon streets.
18. Helped Rick repair backhoe.
19. Todd and Roberto from USGS were here to works on their equipment at well 2.
20. Talking to Unifirst about uniforms.
21. Verizon's circuits to the wells and pumping equipment went out of service 2 times this month leaving us with no communication to the wells. Spent 11 extra hours making sure the water system ran properly until Verizon could find and fix the problem.



Scott Kimball, Superintendent
Water Department