



TOWN OF BRIDGEVILLE

WWTP Monthly Report for July, 2015

Date: August 4, 2015

FLOW REPORT

BRIDGEVILLE		GREENWOOD
298,000 gallons 7/2/15	MAXIMUM AVERAGE TOTAL	64,657 gallons 7/3/15
162,481 gallons per day		58,712 gallons per day
5,036,914 gallons		1,820,086 gallons
TOT. COMB. FLOW (GALS) : 6,857,000 TOT. COMB. AVG. 221,190 GPD		
GREENWOOD'S PRECENTAGE OF TOTAL COMBINED FLOW : 27 %		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE : 31

AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 221,190 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE: 6,857,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED : 21

TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 19,445,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 7/6/15 – The spray rigs at the Spray Farm experienced their first flat tire since being put into operation in 2009. Public Works staff assisted with its removal, repair and installation.
- 2.) 7/8/15 – A contractor repaired Clarifier #1 concrete retaining wall after it showed signs of leakage.
- 3.) 7/8/15 – The Commissioner Report for June 2015, the DMR for June 2015, and the Greenwood Quarterly billing report were completed and submitted.
- 4.) 7/10/15 – Wastewater staff assisted the Street Dept. by cutting grass on both sides of the entry road.
- 5.) 7/13/15 – Wastewater staff began painting digester doors and the hand rails on Clar. 2.
- 6.) 7/17/15 – Wastewater staff assisted with the removal of the Bridgeville sign and benches from the park.
- 7.) 7/20/15 – Wastewater staff assisted the Water Dept. with the installation of a 2 inch water meter at Colonial Gardens Apartments.
- 8.) 7/22/15 – The SEMR for June 2015 was completed and submitted.
- 9.) 7/23/15 – 3 CO inspections inspections were performed at Heritage Shores.

Respectfully submitted,



Jeff Collins
Wastewater Superintendent