



**TOWN OF BRIDGEVILLE**

WWTP Monthly Report for March, 2015

Date: April 8, 2015

**FLOW REPORT**

<b>BRIDGEVILLE</b>		<b>GREENWOOD</b>
409,000 gallons 3/4/15	<b>MAXIMUM AVERAGE TOTAL</b>	101,638 gallons 3/5/15
224,330 gallons per day		74,508 gallons per day
6,954,242 gallons		2,309,758 gallons
<b>TOT. COMB. FLOW ( GALS ) : 9,264,000    TOT. COMB. AVG.    298,839    GPD</b>		
<b>GREENWOOD'S PERCENTAGE OF TOTAL COMBINED FLOW :    25 %</b>		

**NPDES PERMIT REPORT**

**TOTAL DAYS OF STREAM DISCHARGE : 23**

**AVERAGE DAILY FLOW TO STREAM DISCHARGE : 284,000 GPD**

**TOTAL FLOW TO STREAM DISCHARGE : 6,550,000 GALLONS**

**TOTAL NPDES PERMIT VIOLATIONS : 0**

## SPRAY IRRIGATION PERMIT REPORT

**TOTAL DAYS OF SPRAY DISCHARGE : 8**

**AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 339,000 GALLONS**

**TOTAL FLOW TO SPRAY DISCHARGE: 2,714,000 GALLONS**

**TOTAL DAYS SPRAY IRRIGATED : 4**

**TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 4,107,000 GALLONS**

**TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0**

### SUPERINTENDENT'S REPORT

- 1.) 3/3/15 – The Commissioner's report for February 2015 was completed and submitted.
- 2.) 3/5-6/15 – Wastewater staff assisted the Street Department with plowing snow and applying salt.
- 3.) 3/9/15 – The WWTF switched over to stream discharge due to the storage pond at the Spray Farm reaching capacity.
- 4.) 3/17/15 – Super. Collins completed an online continuing education course offered by DTCC.
- 5.) 3/19/15 – RBC A2's domes were re-installed over the empty A2 compartment to remedy safety concerns.
- 6.) 3/25/15 – Quarterly pre-treatment testing was performed at Pet Poultry Products and Rapa.
- 7.) 3/26/15 – Super. Collins attended the Wastewater Workshop held at Town Hall, where future plans for upgrading the treatment process at the WWTF were discussed.

Respectfully submitted,



Jeff Collins

Wastewater Superintendent