



TOWN OF BRIDGEVILLE

WWTP Monthly Report for May, 2015

Date: June 3, 2015

FLOW REPORT

BRIDGEVILLE		GREENWOOD
312,000 gallons 5/21/15	MAXIMUM AVERAGE TOTAL	71,395 gallons 5/21/15
162,377 gallons per day		64,849 gallons per day
5,033,688 gallons		2,010,312 gallons
TOT. COMB. FLOW (GALS) : 7,044,000 TOT. COMB. AVG. 227,000 GPD		
GREENWOOD'S PRECENTAGE OF TOTAL COMBINED FLOW : 29 %		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE : 31

AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 227,000 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE: 7,044,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED : 10

TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 6,706,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 5/1/15 – Wastewater staff assisted Street Dept. with repairs to street sweeper.
- 2.) 5/4/15 – Wastewater staff completed the planned sewer cleanout inspection project in Heritage Shores. The project entails locating the cleanout, verifying that it is properly sealed, and notifying the homeowner should any repairs have to be made. This occurred on all streets that have currently been accepted by the Town.
- 3.) 5/5/15 – Wastewater staff assisted Water Dept. with the installation of a 1 inch water meter.
- 4.) 5/5/15 – The Commissioner's Report for April 2015 was completed and submitted.
- 5.) 5/12/15 – Wastewater staff attended a DFIT meeting about "Lifting Safety" held at the Rehoboth Beach convention center.
- 6.) 5/13/15 – A contractor unblocked the pipe and manifold that supplies flow to RBC basin "A".
- 7.) 5/19/15 – A member of the wastewater staff attended the regularly scheduled DFIT meeting held in Dover.
- 8.) 5/28/15 – Both State reports (DMR and SEMR) were completed and submitted.

Respectfully submitted,



Jeff Collins
Wastewater Superintendent