



WATER DEPARTMENT MARCH 2015 MONTHLY REPORT

<u>Water Supplied this month</u>	5,715,100 gallons
<u>Average Daily Water Supplied</u>	184,358 gallons
<u>Water produced Y.T.D</u>	17,053,300 gallons

Water and Sewer Inspections

Pro-shop Heritage Shores
30 Royal view Dr.

Sewer Extension Inspections

New Water Meters and MXU's Installed

7 Champions Dr. – 2 meters/ 1 mxu
7 Champions Dr. – 2 meters/ 1 mxu
39 Harlequin Loop - 2 meters/ 1 mxu
Pro-shop – 1 meter/ 1 mxu
30 Royal view Dr. – 2 meters/ 1 mxu
106 Edgewood – 1 mxu
108 Edgewood – 1 mxu
20 Champions Dr. – 1 meter (froze and busted)
65 Canvasback Cr. – 1 meter (bad meter)
43 Snowy Egret Ct. – 1 meter (bad meter)
30 Gadwall – 1 meter (bad meter)
72 Emily's pintail Dr. – 1 meter (bad meter)

Final Readings

Wawa
5 Champions Dr.
101 Jacobs Ave
10 Ruddy duck Dr.
45 Canvasback Cr.
39 Harlequin Loop
4 Elm St.
28 Champions Dr.
31 Amanda teal Dr.

C.O. Inspections

28 Champions Dr.
39 Harlequin loop
5 Champions Dr.

Meters removed : 1

15 Church St.
410/412 Market St.

Service Calls : 23

Shut-offs : 6

1. Water meter readings
2. Routine samples and readings at wells
3. Monthly water samples and usage report for the Office of Drinking Water
4. Performed routine duties and regular maintenance
5. Turned in report for public works time spent at phase 3
6. Meetings with Town Manager
7. Water meter replacement project still in progress
8. Plowed snow
9. The fire hydrant at Jimmy's grill was repaired and put back in service
10. Spent time correcting meter information for Town hall
11. Had meeting with Ed Denver from L&B Water
12. Roberto Cruz from USGS here to check their equipment at well 2
13. Purchased safety harness and double lanyard
14. Ordered fire hydrant flow test kit
15. Ordered meter test kit
16. Did various Miss Utility locate tickets
17. A.P. Croll was here doing punch list items from walk through

The water department has experienced a large number of re-reads this past month. Due to the replacement of aged meters, the new meters are very sensitive and will read done to 100th of a gallon. The old meters may have not been accurate, but be assured the new meters are counting every drop.



Scott Kimball, Superintendent
Water Department