



WATER DEPARTMENT APRIL 2015 MONTHLY REPORT

<u>Water Supplied this month</u>	5,750,500 gallons
<u>Average Daily Water Supplied</u>	191,683 gallons
<u>Water produced Y.T.D</u>	22,803,800 gallons

Water and Sewer Inspections

26 Royal view Dr.
34 Royal view Dr.
27 Champions Dr.
29 Champions DR.
149 Champions Dr.
Whistling duck Dr.
15 Whistling duck Dr.
17 Whistling duck Dr.
31 Whistling duck Dr.
33 Whistling duck Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

27 Champions Dr. – 2 meters/ 1 mxu
29 Champions Dr. – 2 meters/ 1 mxu
149 Champions Dr. - 2 meters/ 1 mxu
26 Royal view Dr. – 2 meter/ 1 mxu
34 Royal view Dr. – 2 meters/ 1 mxu
31 Whistling duck Dr.- 2 meters/ mxu
33 Whistling duck Dr. – 2 meters/1 mxu
9 Whistling duck dr. – 2 meters/1mxu
15 Whistling duck Dr. 2 meters/1 mxu
17 Whistling duck – 2 meters/1mxu
2 Gadwall – 1 meter (bad meter)
23 Ruddy duck Ln. – 1 meter (bad meter)
45 Whistling duck Dr. 1 meter/1 mxu
77 Amanda teal Dr. 1 meter/1mxu
ECEC Phyllis Wheatly – 1 meter/ 1mxu
7451 Federalsburg Rd. – 1 mxu (bad mxu)
98 Whistling duck Dr. – 1 mxu (bad mxu)

Final Readings

25 White Pelican Ct.
31 Amanda teal Dr.

C.O. Inspections

30 Royal view Dr.
47 Canvasback Cir.

Meters removed : 0

Service Calls : 14

Shut-offs : 2

1. Water meter readings
2. Routine samples and readings at wells
3. Monthly water samples and usage report for the Office of Drinking Water
4. Performed routine duties and regular maintenance
5. Turned in report for public works time spent at phase 3
6. Meetings with Town Manger
7. Spent time correcting meter information for Town hall
8. Roberto Cruz from USGS here to check their equipment at well 2
9. Did various Miss Utility locate tickets
10. Had leak repaired at Walnut and Cherry (water main project)
11. Finished water meter project
12. Repaired water feed line on soda ash mixer
13. Turned in FY 2016 budget
14. Attended budget workshop
15. Mowed grass at well6, H.S. water tower, and H.S. lift station
16. Helped Rick measure roads in H.S.
17. Replaced 15 faulty meter cables
18. Made spreadsheet for Sensus, for research on cable issue



Scott Kimball, Superintendent
Water Department