



## WATER DEPARTMENT MARCH 2016 MONTHLY REPORT

<u>Water Supplied this month</u>	5,360,600 gallons
<u>Average Daily Water Supplied</u>	172,923 gallons
<u>Water produced Y.T.D</u>	18,336,800 gallons

### Water and Sewer Inspections

11 Harlequin Loop  
7 Harlequin Loop  
10 Champions Dr.  
308 S. Main St.  
306 Cedar St. – water only  
137 Waterside Dr.  
139 Waterside Dr.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

23 Harlequin Loop – 2 meters/ 2 mxu  
145 Champions Dr. – 2 meters/ 2 mxu  
11 Harlequin Loop – 2 meters/2 mxu  
10 Champions Dr. – 2 meters/2 mxu  
137 Waterside Dr. – 2 meters/2 mxu  
139 Waterside Dr. 2meters/2 mxu  
63 Church St. – 1 mxu  
45 Whistling duck Dr. – 1 mxu  
35 Whistling duck Dr. – 1 meter

### Final Readings

23607 Linkside Dr.  
23609 Linkside Dr.  
15 Champion Dr.  
3 Harlequin Loop  
7 Harlequin Loop  
206 Walnut St.  
38 Waterside Dr.  
4 Elm St.  
151 Champion Dr.  
37 Ruddy duck Dr.

### C.O. Inspections

15 Champions Dr.  
151 Champions Dr.  
7 Harlequin Loop

**Meters removed : 3**


309 Market St.

14 Amanda teal – house and Irr.

**Service Calls : 20**

**Shut-offs : 8**

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Helped change gearbox on spray rig.
8. USGS here to calibrate their equipment.
9. Conducted interviews for Public Works position.
10. Helped repair pipe at waste water plant.
11. Replaced flow switch on Well 5D.
12. Had generators at the wells fueled.
13. Fixed gutter down spouts at well 5.
14. Had meeting with Ed and Dave from L&B Water, installed UNIPRO software.
15. Repaired RPZ backflow preventers at wells 2 and 5. ( springs, plungers, and o-rings)
16. Repaired wind damaged fence at H.S. water tower with Jeff.
17. Replaced broken outside faucet at Town Hall.
18. Submitted Equipment list for insurance company.
19. Purchased 2” RPZ for fire hydrant application.
20. Purchased new HACH DR900 colorimeters to replace 10 year old ones.
21. Ordered fire hydrant parts for Canterbury Apts. – struck by vehicle. Put O/S.
22. Fixed eye wash station at well 2.
23. Helped Jerry and Jeff with flag pole.
24. Had meeting with Joe from American Darling. Scheduled in house training.



---

Scott Kimball, Superintendent  
Water Department