



WATER DEPARTMENT JANUARY 2015 MONTHLY REPORT

<u>Water Supplied this month</u>	5,761,800 gallons
<u>Average Daily Water Supplied</u>	185,865 gallons
<u>Water produced Y.T.D</u>	5,761,800 gallons

Water and Sewer Inspections

6 Champions Dr.
47 Harlequin Loop

Sewer Extension Inspections

New Water Meters and MXU's Installed

100 Whistling duck Ln. – replaced 1 bad meter
100 Whistling duck Ln. – replaced 1 bad MXU
2 Champions Dr. -2 meters/ 1 MXU
4 Champions Dr. – 2 meters/ 1 MXU
5 Champions Dr. – 2 meters/ 1 MXU
7 Champions Dr. – 2 meters/ 1 MXU
3 Blue Heron Ct. – 2 meters/ 1 MXU

Final Readings

103 Jacobs Ave.
35 Amanda Teal Dr.
26 Champions Dr.

C.O. Inspections

26 Champions Dr.
13 Ruddy duck Ln.

Meters removed : 2

3 Blue Heron Ct. – Irr.(H.S. HOA)
502 S. Cannon St.

Service Calls : 20

Shut-offs : 7

1. Water meter readings
2. Routine samples and readings at wells
3. Monthly water samples and usage report for the Office of Drinking Water
4. Performed routine duties and regular maintenance
5. Turned in report for public works time spent at phase 3
6. Meetings with Town Manager
7. Walnut St. project completed
8. Started meter replacement project
9. Spent numerous hrs. on meter replacement project
10. USGS was here to check their equipment at well 2
11. Repaired injection fitting at Well 5 (Carus pump)
12. Repaired M-Scope
13. Updated office forms and worksheets
14. Completed DNREC Allocations report
15. Had door lock repaired at Well5
16. Made new floats for chemical barrels
17. Took Jason from DBF and Brian from Tieder to well sites for Comm. Upgrade project
18. Marked various Miss Utilities locate tickets
19. Flushed fire hydrants



Scott Kimball, Superintendent
Water Department