

TOWN OF BRIDGEVILLE

WWTP Monthly Report for April, 2016

Date: May 4, 2016

FLOW REPORT

BRIDGEVILLE	MAXIMUM AVERAGE TOTAL	GREENWOOD
266,000 gallons 4/12/16		63,,205 gallons 4/8/16
173,733 gallons per day		60,567 gallons per day
5,211,993 gallons		1,817,007 gallons
TOT. COMB. FLOW (GALS): 7,029,000 TOT. COMB. AVG. 234,300 GPD		
GREENWOOD’S PRECENTAGE OF TOTAL COMBINED FLOW : 26%		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE (TO POND): 30

AVG. DAILY FLOW TO SPRAY DISCHARGE (TO POND): 234,300 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE (TO POND): 7,029,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED (TO FIELDS): 5


TOTAL SPRAY IRRIGATED FOR MONTH (TO FIELDS) 3,564,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 4/1/16 – HIE calibrated all of the waste treatment plant's flow meters. This is a requirement of the NPDES permit and must be done annually.
- 2.) 4/4/16 – New Water/Wastewater Dept. employee Scott Walls arrived for his first day with the Town.
- 3.) 4/5/16 – The DMR for March 2016 was submitted both via email and through DNREC's new electronic E-DMR reporting system.
- 4.) 4/11/16 – Clean Delaware hauled and applied approx. 78 tons of processed biosolids that the WWTF had been storing for the past year.
- 5.) 4/18/16 – Wastewater staff filled potholes with what remaining cold patch was available.
- 6.) 4/22/16 – The summer corn crop planting was completed by the new farmer, Jesse Vandewende.
- 7.) 4/27/16 – A revised 4.04 report was submitted to DNREC. This report is submitted annually or when personnel changes at the WWTF occur.
- 8.) 4/27/16 – The SEMR for March 2016 was completed and mailed.
- 9.) 4/29/16 – A sewer complaint was received from 200 Railroad Ave.

Respectfully submitted,



Jeff Collins
Wastewater Superintendent