



TOWN OF BRIDGEVILLE

WWTP Monthly Report for June, 2015

Date: July 7, 2015

FLOW REPORT

BRIDGEVILLE		GREENWOOD
327,000 gallons 6/20/15	MAXIMUM AVERAGE TOTAL	147,505 gallons 6/25/15
173,317 gallons per day		58,816 gallons per day
5,199,516 gallons		1,764,484 gallons
TOT. COMB. FLOW (GALS) : 6,964,000 TOT. COMB. AVG. 232,000 GPD		
GREENWOOD'S PERCENTAGE OF TOTAL COMBINED FLOW : 25 %		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE : 31

AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 232,130 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE: 6,964,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED : 12

TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 11,522,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 6/1/15 – The DMR for May 2015 was completed and submitted via e-mail.
- 2.) 6/3/15 – The Commissioner's Report for May 2015 was completed and submitted.
- 3.) 6/9/15 – The SEMR for May 2015 was completed and submitted.
- 4.) 6/10/15 – Quarterly samples were conducted at Rapa and Pet Poultry Products. These samples are required by permit.
- 5.) 6/18/15 – Public Works staff worked to remove a stuck manhole at the corner of Oak and N. Cannon. It was finally removed when it was cut into 3 pieces with a gas saw and pulled out using the backhoe.
- 6.) 6/22/15 – Wastewater staff completed gearbox oil changes on Spray rig 2. Each rig has 12 gearboxes.
- 7.) 6/24/15 – The spray field lysimeters were sampled and tested. This is required monthly by permit.
- 8.) 6/25/15 – The WWTF completed a mandatory 1 hour generator run test required by ECS to meet their requirements to remain in the energy reduction program.
9. 6/26/15 – Wastewater staff attended the Employee Luncheon at Town Hall.

Respectfully submitted,



Jeff Collins
Wastewater Superintendent