



TOWN OF BRIDGEVILLE

WWTP Monthly Report for September, 2015

Date: October 6, 2015

FLOW REPORT

BRIDGEVILLE		GREENWOOD
352,000 gallons 9/29/15	MAXIMUM	68,966 gallons 9/30/15
158,800 gallons per day	AVERAGE	61,332 gallons per day
4,764,001 gallons	TOTAL	1,839,989 gallons
TOT. COMB. FLOW (GALS) : 6,604,000 TOT. COMB. AVG. 220,130 GPD		
GREENWOOD'S PERCENTAGE OF TOTAL COMBINED FLOW : 28%		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE : 30

AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 220,130 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE: 6,604,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED : 3

TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 3,077,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 9/8/15 – The Commissioner's Report for August 2015 and the DMR for August 2015 were completed and submitted.
- 2.) 9/9/15 – Wastewater staff assisted the Water Dept. with work related to the new water system radio control project.
- 3.) 9/10/15 – Super. Collins attended the Pre-Construction meeting for the Bridgeville Branch restoration project.
- 4.) 9/11/15 – CO inspections were performed at 147 Champion and 19 Whistling Duck.
- 5.) 9/15/15 – Quarterly pre-treatment testing was performed at Rapa and Pet Poultry Products.
- 6.) 9/17/15 – A copy of the WWTF Storm Water Pollution Prevention Plan (SWPPP) was submitted for review by the Storm Water section of DNREC.
- 7.) 9/23/15 – The SEMR for August 2015 was completed and submitted.
- 8.) 9/28/15 - The lysimeters at the Spray Farm were sampled and sent for testing.
- 9.) 9/30/15 – Super. Collins met with representatives from Dollar General pertaining to the new gravity sewer line on John St to be installed as part of the construction project.

Respectfully submitted,



Jeff Collins
Wastewater Superintendent