



TOWN OF BRIDGEVILLE

WWTP Monthly Report for October, 2014

Date: November 3, 2014

FLOW REPORT

BRIDGEVILLE		GREENWOOD
324,000 gallons 10/15//14	MAXIMUM AVERAGE TOTAL	72,550 gallons 10/31/14
140,918 gallons per day		66,985 gallons per day
4,368,452 gallons		2,076,548 gallons
TOT. COMB. FLOW (GALS) : 6,445,000 TOT. COMB. AVG. 208,000 GPD		
GREENWOOD'S PRECENTAGE OF TOTAL COMBINED FLOW : 32%		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0 GPD

TOTAL FLOW TO STREAM DISCHARGE : 0 GALLONS

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE : 31

AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 208,000 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE: 6,445,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED : 10

TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 6,819,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 10/1/14 – Wastewater staff assisted the Water Dept. with attempting to shut off water on Walnut St. as part of the water line replacement project.
- 2.) 10/2/14 – Super. Collins made contact with Mountain Machine Works (MMW) about repair of the broken shaft on RBC A4. Received repair quote later in the day and forwarded via email to Town Manager Savage and DBF.
- 3.) 10/9/14 – A pre-construction meeting was held at the WWTF pertaining to replacement of the effluent line.
- 4.) 10/10-11/14 – Wastewater staff assisted the Street Dept. with setting out and deploying barricades and safety cones as part of the Apple-Scrapple Festival.
- 5.) 10/13/14 – Town Commissioners approved the repair of RBC A4 by MMW. After speaking with MMW the next day, the repair was set for 10/28/14 through 10/30/14.
- 6.) 10/16/14 – Wastewater staff assisted the Water Dept. with the installation of a 2 inch water meter.
- 7.) 10/28-30/14 – MMW repaired the broken shaft on RBC A4, which was put back in service around Noon on 10/30/14.
- 8.) 10/28/14 – A call-in alarm was received from the WWTP, caused by a power blip.
- 9.) 10/31/14 – Wastewater staff assisted the Water Dept. with setting up to drain the Heritage Shores water tower for maintenance.

Respectfully submitted,



Jeff Collins

Wastewater Superintendent