



TOWN OF BRIDGEVILLE

WWTP Monthly Report for February, 2015

Date: March 3, 2015

FLOW REPORT

BRIDGEVILLE		GREENWOOD
408,000 gallons 2/22/15	MAXIMUM AVERAGE TOTAL	84,526 gallons 2/22/15
176,340 gallons per day		69,624 gallons per day
4,937,528 gallons		1,949,472 gallons
TOT. COMB. FLOW (GALS) : 6,887,000 TOT. COMB. AVG. 246,000 GPD		
GREENWOOD'S PERCENTAGE OF TOTAL COMBINED FLOW : 28 %		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE : 31

AVERAGE DAILY FLOW TO SPRAY DISCHARGE : 246,000 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE: 6,887,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED : 5


TOTAL GALLONS SPRAY IRRIGATED FOR MONTH : 3,965,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 2/2/15 – Wastewater staff attended a meeting with DBF to discuss changes to the water and sewer layout in Phase 3B of Heritage Shores.
- 2.) 2/2/15 – The DMR for January 2015 was completed and submitted via e-mail.
- 3.) 2/4/15 – A sewer inspection was performed at 101 Jacobs Ave.
- 4.) 2/4/15 – Super. Collins attended a meeting with DNREC pertaining to the upcoming tax ditch restoration project.
- 5.) 2/11/15 – Super. Collins attended a training class at DTCC to fulfill continuing education requirements to renew operating license.
- 6.) 2/13/15 – Wastewater staff assisted the Water Dept. with frozen or burst pipe complaints.
- 7.) 2/17/15 – Wastewater staff assisted the Street Dept. with snow removal and salting operations.
- 8.) 2/21/15 - Wastewater staff assisted the Water Dept. with frozen or burst pipe complaints.
- 9.) 2/27/15 - Wastewater staff assisted the Street Dept. with snow removal and salting operations.

Respectfully submitted,



Jeff Collins

Wastewater Superintendent