



WATER DEPARTMENT DECEMBER 2014 MONTHLY REPORT

<u>Water Supplied</u>	6,070,700 gallons
<u>Average Daily Water Supplied</u>	195,829 gallons
<u>Water produced in 2014</u>	96,616,200 gallons

Water and Sewer Inspections

2 Champions Dr.
4 Champions Dr.
5 Champions Dr.
7 Champions Dr.
3 Blue Heron Ct.

Sewer Extension Inspections

47 Harlequin Loop

New Water Meters and MXU's Installed

65 Whistling duck Ln. – replaced 1 bad meter
32 Whistling duck Ln. – replaced 1 bad meter
304 Cedar St. – 1 meter/1 MXU
408 Cedar St. – 1 meter/1 MXU

Final Readings

113 Delaware Ave.
1 Blue heron Ct.
304 Edgewood St.
8 Champions Dr.
5 Harlequin Loop
22 Harlequin Loop
69 Whistling duck Ln.
48 Canvasback Cr.

C.O. Inspections

8 Champions Dr.
24 Champions Dr.
5 Harlequin Loop
22 Harlequin Loop
69 Whistling duck Ln.
13 Ruddy duck Ln.


Meters removed : 4

500 Laws St.
109 N. Main St.
2 meters at 45 Whistling duck Ln.

Service Calls : 23 (2014- 217)

Shut-offs : 7 (2014 – 85)

1. Water meter readings
2. Routine samples and readings at wells
3. Monthly water samples and usage report for the Office of Drinking Water
4. Performed routine duties and regular maintenance
5. Turned in report for public works time spent at phase 3
6. Meetings with Town Manager
7. Walnut St. project still in progress (water main and service lines completed)
8. Spent numerous hrs. on Walnut St. project
9. Had 2 new fire hydrants installed on Walnut St.
10. Had 2 bad valves replaced on Delaware Ave. and Pine Alley
11. Safety cables were fixed at both water towers
12. Took Jason from DBF to well sites for Comm. Upgrade project
13. Marked various Miss Utilities locate tickets
14. Attended H.S. phase 3 progress meeting
15. Collected all information for Tidewater's meters at Linkside Village
16. Had a meeting with Schrocks Plumbing about meter project



Scott Kimball, Superintendent
Water Department