



WATER DEPARTMENT NOVEMBER 2014 MONTHLY REPORT

<u>Water Supplied</u>	5,838,100 gallons
<u>Average Daily Water Supplied</u>	194,603 gallons
<u>Water produced Y.T.D. in 2014</u>	90,545,500 gallons

Water and Sewer Inspections

26 Champions Dr.
28 Champions Dr.

Sewer Extension Inspections

None for this month

New Water Meters and MXU's Installed

Harlequin Loop – 2 meters/ 1 MXU
5 Harlequin Loop – 2 meters/ 1MXU
22 Harlequin Loop – 2 meters/1 MXU
201 Market St. – 1 meter/ 1MXU
18 Champions Dr. – 2 meters/1 MXU
20 Champions Dr. – 2 meters/1 MXU
26 Champions Dr. – 2 meters/ 1 MXU
28 Champions Dr. – 2 meters/ 1 MXU
80 Whistling duck Dr. 2 meters/ 1 MXU
13 Ruddy duck Ln. – 2 meters/ 1 MXU
47 Canvasback Cir. – 2 meters/1 m\MXU
1 Blue heron Ct. 2 meters/ 1 MXU

Final Readings

36 White Pelican Ct.
126 Emily Pintail Dr.
8 Amanda Teal Dr.
40 Snowy Egret Ct.
35 Whistling duck Dr.
115 Emily Pintail Dr.
10 Ruddy duck Ln.

C.O. Inspections

48 Canvasback Cir.
40 Snowy Egret Ct.
35 Whistling duck Ln.
1 Blue Heron Ct.


Meters removed : 1

1 Blue Heron Ct. (HOA- Common area)

Service Calls : 20

Shut-offs : 2

1. Water meter readings
2. Routine samples and readings at wells
3. Monthly water samples and usage report for the Office of Drinking Water
4. Performed routine duties and regular maintenance
5. Turned in report for public works time spent at phase 3
6. Meetings with Town Manager
7. Walnut St project in progress
8. Spent several hrs. on Walnut St. project
9. Had progress meeting for Walnut St, project
10. Heritage Shores water tower had annual maintenance performed
11. Had drain valve installed at Heritage Shores water tower
12. Took BAC-T and VOC samples at H.S. water tower
13. Replaced filter on Town hall water cooler
14. Replaced diaphragm on well 6 soda ash pump
15. USGS checked their equipment at well2
16. Attended class at DRWA – CUPPS training
17. Did inspection with Dean Du'be and Bryan and sons –(phase 1B&2A), also did White Pelican and Blue heron Cts.
18. Fixed M-scope (well monitoring device)
19. Worked on inventory report



Scott Kimball, Superintendent
Water Department