



WATER DEPARTMENT MAY 2016 MONTHLY REPORT

<u>Water Supplied this month</u>	6,984,200 gallons
<u>Average Daily Water Supplied</u>	225,297 gallons
<u>Water produced Y.T.D</u>	31,190,100 gallons

Water and Sewer Inspections
None this month

Sewer Extension Inspections
None this month

New Water Meters and MXU's Installed
None this month

Final Readings
139 Waterside Dr.
416 Laws St.
23605 Link side Dr.

C.O. Inspections
139 Waterside Dr.

Meters removed : 2
6 Church St.
8 Church St.

Service Calls : 14

Shut-offs : 7

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Flushed fire hydrants.
8. Mowed grass and sprayed weeds at wells, lift station, and water tower.
9. USGS here to calibrate their equipment.
10. Replaced dead battery in Rick's truck.
11. Training Scott W. on various operations of the Water Dept.
12. Fixed chlorine pump at well 5.
13. Put new Hach DR 900 colorimeters at wells 5 and 6.
14. Had meeting with EPA, Town manager, and DBF about water department projects.
15. Helped Phillip fill pot holes.
16. Repaired fire hydrant at Canterbury Apts.
17. Had meeting with Sherri from DRWA.
18. Helped in the repair process of fixing sink hole on Rail road Ave.
19. Had water dept. truck fixed. (oil filter housing and turbo charger)
20. CCR Report for 2015 completed.

Copies of the 2015 CCR Report were sent to the Office of Drinking Water and the State Advocates Office.

Hard copies of the 2015 CCR Report have been posted in Town hall, Library, Post office and Mowbray's Barbershop.

I have turned the 2015 CCR Report into Town hall and it will be posted on the Town website and sent out in the next newsletter.



Scott Kimball, Superintendent
Water Department