



## WATER DEPARTMENT JUNE 2016 MONTHLY REPORT

<u>Water Supplied this month</u>	9,915,000 gallons
<u>Average Daily Water Supplied</u>	330,500 gallons
<u>Water produced Y.T.D</u>	41,105,100 gallons

### Water and Sewer Inspections

26 Waterside dr.  
123 waterside dr.  
43 Waterside Dr.  
27 Waterside dr.  
5 Legends Way  
16 Champions dr.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

26 Waterside Dr. – 2 meters/ 2 mxus  
123 Waterside Dr. – 2 meters/ 2 mxus  
43 Waterside Dr. – 2 meters/2 mxus  
27 Waterside Dr. – 2 meters/2 mxus  
103 Whistling duck Dr. 1 meter (Irr.)  
AG building ( Woodbridge middle school) – 1 meter  
500 S. Cannon St. reinstalled 1 meter/1 mxu  
Gadwall common area north Irr. – 1 meter

### Final Readings

137 Waterside Dr.  
145 Champions Dr.  
69 Canvasback Cr.  
69 Emily Pintail  
10 Champions Dr.

### C.O. Inspections

137 Waterside Dr.

### Meters removed : 1

500 N. Cannon St.

### Service Calls : 23


### Shut-offs : 5

1. Water meter readings.
2. Monthly water samples and usage report for the Office of Drinking Water.
3. Performed routine duties and regular maintenance.

4. Meetings with Town Manger.
5. Did various Miss Utility locate tickets.
6. Flushed fire hydrants.
7. Mowed grass and sprayed weeds at wells, lift station, and water tower.
8. USGS here to calibrate their equipment.
9. Training Scott W. on various operations of the Water Dept.
10. Located buried valve box on Heritage Shores Cr.
11. Met with Dean Du'be about meter pit lids in phase III.
12. Fixed soda ash pump at well 6.
13. Helped hang new banners in town.
14. Put new lid on valve box at Library.
15. Helped Jerry put up DO NOT ENTER sign.
16. Had meeting with Jason (DBF) – Oak St. and Phase III submittials.
17. Installed new handicap toilet at Town Hall.
18. Repaired old toilet at Town Hall.
19. Checked fire hydrants in town limits (8) – nozzle recall from American.
20. Ordered new parts for Hydrants – recall from American.
21. Went over 2012 Water Facility Plan with Town Manager.

There are two issues I need to explain more in depth this month.

1. American Flow Control has issued a recall on hose adapters on fire hydrants manufactured from 2006-2011. We have checked the fire hydrants in town limits and have found 8. They will be inspected further and fixed as soon as possible.
2. I have spoken with Town Manger Jesse Savage about the mildew issue on the Heritage Shores water tower. We received an estimate of \$25,000 to pressure wash it from a third party contractor. Our maintenance contract was sold by Caldwell Tanks to Utilities Management Group. I have spoken with Russel Brown from UMG, they will be sending a representative here to inspect the tanks and to go over our contract and to give us an estimate to clean the tank. He also recommended not to let the fire company spray down the tank that it could cause more damage to the surface of the tank. I have not been contacted yet, as soon as I get more information, I will discuss with the Town Manager



---

Scott Kimball, Superintendent  
Water Department