



## WATER DEPARTMENT SEPTEMBER 2016 MONTHLY REPORT

<u>Water Supplied this month</u>	10,577,500 gallons
<u>Average Daily Water Supplied</u>	352,583 gallons
<u>Water produced Y.T.D</u>	75,272,300 gallons

### Water and Sewer Inspections

135 Waterside Dr.  
33 Waterside Dr.  
59 Champions Dr.  
141 Champions Dr.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

112 Jacobs St. – 1 mxu  
5 Canvasback Cir. – 1 meter  
9 Amanda teal Dr. – 1 meter  
1 Blue Heron Ct. – 1 meter  
135 Waterside Dr. – 2 meters / 2 mxus

### Final Readings

400 Cedar St.  
203 Market St.  
113 Delaware Ave.  
109 Jacobs St.  
36 Waterside Dr.  
108 Wills Isl.  
19 Oak St.  
25 Oak St.

### C.O. Inspections

5 Legends Way

Meters removed : 0

Service Calls : 17

Shut-offs : 3

1. Water meter readings.
2. Monthly water samples and usage report for the Office of Drinking Water.
3. Performed routine duties and regular maintenance.
4. Meetings with Town Manger.
5. Did various Miss Utility locate tickets.
6. Flushed fire hydrants.
7. Inspected valve boxes that were adjusted during S. Main St. and Edgewood St. state project.
8. Completed the Lead and Copper sampling paper work and sent it to the proper authorities. All is good. We will sample again in 2019.
9. Helped Rick with the mower repair.
10. Replaced diaphragm on Well 6 soda ash pump.
11. Had storm water training at WWTP.
12. Showed Rick the new equipment at the wells.
13. Helped Rick unclog pipes at Frog harbor.
14. Had fire hydrant I.D. stickers made.
15. Fixed fire hydrant at H.S. pool. Was missing a pin that held coupling to valve rod.
16. Sent Jesse Savage information on Chromium 6, that was in the news last week.
17. Scheduled water tower maintenance on the following dates for interior washing and inspection.  
Tank 1(in town) 11/1/16 – will start draining on 10/28/16  
Tank 2 (H.S.) 11/15/16 – will start draining on 11/11/16
18. Found and marked valve boxes on Heritage Shores Cir. to be dug up and fixed by Brookfield that were covered up when Gaines moved fire hydrant during phase 3A. This area not accepted by the Town.
19. Had Hopkins construction come to fix broken valve box and valve on Heritage Shores Cir. that has been accepted by the Town. We replaced the broken valve box and cleaned out 2 other valve boxes that were filled with black top, we found that the valve was not broken as I thought. We are still waiting to have it repaved due to weather.



---

Scott Kimball, Superintendent  
Water Department