



TOWN OF BRIDGEVILLE

WWTP Monthly Report for October, 2016

Date: November 8, 2016

FLOW REPORT

BRIDGEVILLE		GREENWOOD
786,000 gallons 10/9/16	MAXIMUM AVERAGE TOTAL	171,846 gallons 10/9/16
294,576 gallons per day		72,328 gallons per day
9,131,843 gallons		2,242,157 gallons
TOT. COMB. FLOW (GALS): 11,374,000 TOT. COMB. AVG. 366,900 GPD		
GREENWOOD'S PRECENTAGE OF TOTAL COMBINED FLOW : 20 % (19.7)		

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE : 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE : 0

TOTAL FLOW TO STREAM DISCHARGE : 0

TOTAL NPDES PERMIT VIOLATIONS : 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE (TO POND): 31

AVG. DAILY FLOW TO SPRAY DISCHARGE (TO POND): 366,900 GALLONS

TOTAL FLOW TO SPRAY DISCHARGE (TO POND): 11,374,000 GALLONS

TOTAL DAYS SPRAY IRRIGATED (TO FIELDS): 15

TOTAL SPRAY IRRIGATED FOR MONTH (TO FIELDS) 13,579,000 GALLONS

TOTAL SPRAY IRR. PERMIT VIOLATIONS: 0

SUPERINTENDENT'S REPORT

- 1.) 10/3/16 – The Commissioner's Report for September 2016 was completed and submitted.
- 2.) 10/4/16 – A sewer complaint from N. Cannon St. was received. It was ultimately determined that the issue was the responsibility of the homeowner to fix.
- 3.) 10/10/16 – The DMR for September 2016 was completed and transmitted to DNREC electronically, marking the first time the report was submitted without a paper copy submitted as well.
- 4.) 10/13/16 – A control float issue at Gateway Plaza lift station (Sonic) was discovered and repaired.
- 5.) 10/17/16 – An alarm call was received and responded to around 11:00 PM for a raw well pump issue.
- 6.) 10/20/16 – The SEMR for September 2016 was completed and submitted, both electronically and a hard copy via the USPS.
- 7.) 10/21/16 – Wastewater staff started posting smoke testing notification flyers on homes within the targeted smoke testing areas.
- 8.) 10/24/16 – The monthly AOC packet, required by the EPA and DNREC, was completed, certified and mailed.

Respectfully submitted,



Jeff Collins
Wastewater Superintendent