



WATER DEPARTMENT OCTOBER 2016 MONTHLY REPORT

<u>Water Supplied this month</u>	7,362,100 gallons
<u>Average Daily Water Supplied</u>	237,487 gallons
<u>Water produced Y.T.D</u>	82,634,400 gallons

Water and Sewer Inspections

143 Champions Dr.
9 Harlequin Loop
14 Champions Dr.
1 Champions Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

300 Laws St. – 1 meter/ 1mxu
33 Waterside Dr. – 2 meters/ 2 mxus
9 Harlequin Loop – 2 meters/ 2 mxus
84 Whistling duck – 1 meter
30 Waterside Dr. – 2 meters / 2 mxus
14 Champions Dr. – 2meters/ 2 mxus
1 Champions dr. – 2 meters / 2mxus
59 Champions dr. – 2 meters / 2mxus
143 Champions dr. – 2 meters / 2 mxus
141 Champions Dr. – 2 meters /2 mxus

Final Readings

315 S. Main St.
30 Gadwall Cr.
135 Waterside Dr.
19 Harlequin loop
30 Waterside Dr.
16 Champions Dr.

C.O. Inspections


16 Champions Dr.
135 Water side Dr.
30 Water side Dr.
19 Harlequin Loop

Meters removed : 0

Service Calls : 11

Shut-offs : 3

1. Water meter readings.
2. Monthly water samples and usage report for the Office of Drinking Water.
3. Performed routine duties and regular maintenance.
4. Meetings with Town Manger.
5. Did various Miss Utility locate tickets.
6. Flushed fire hydrants.
7. Attended DRWA Expo in Milford De.
8. Attended DRWA hydrant class in Leipsic De.
9. Put out and picked up Water Dept. equipment for Apple-Scrapple festival.
10. Helped Rick work on utility trailer.
11. Helped Rick with Apple-Scrapple Festival.
12. Picked up and returned light towers to Greenwood.
13. Checked valve pits at H.S. for the section we are getting ready to take over.
14. Sent in application for my W.W. license renewal.
15. Broke M- scope for monitoring wells during regular maintenance. Will need to purchase a new one.
16. Ordered polo shirts for Public Works Departments.
17. Had a meeting with L&B Water and Town Manager about our meter reading equipment, they are phasing out our current equipment(antennas) and we will have to up-grade to the new ones in the near future. The new equipment will be able to read the old and the new at the same time.
18. The Water Dept. (F-350) has blown a head gasket and is leaking anti- freeze. We have temporarily fixed the problem for now with leak stop. It is approximately \$4000.00 to fix. It was brought to the to the attention of the Town Manager that we may want to start looking for a new truck do to its age and that it is requiring major repairs on a regular basis.
19. Took in town water tower (W.T. #1) off line for scheduled interior inspection and cleaning.



Scott Kimball, Superintendent
Water Department