



WATER DEPARTMENT JANUARY 2017 MONTHLY REPORT

<u>Water Supplied this month</u>	5,552,800 gallons
<u>Average Daily Water Supplied</u>	179,123 gallons
<u>Water produced Y.T.D</u>	5,552,800 gallons

Water and Sewer Inspections

41 Waterside Dr.
39 Waterside Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

35 Waterside Dr. – 2 meters/ 2 mxu
127 Waterside Dr. – 2 meters/ 2 mxu
108 Jacobs Ave. – 1 meter – replacement
28 Waterside Dr. – 2 meters/2 mxu

Final Readings

23 Canvasback Dr.
66 Emily's Pintail
28 Waterside Dr.
35 Waterside Dr.
210 S. Main St.

C.O. Inspections

28 Waterside Dr.
35 Waterside Dr.

Meters removed : 2

302 Sussex Ave.
510 N. Cannon St.

Service Calls : 16

Shut-offs : 8

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Finished and submitted DNREC allocation report.
8. Plowed snow.
9. Submitted water loss calculations to the Town manager.
10. Tieder Electric fixed HMI screen at Heritage Shores water tower.
11. Did evaluations.
12. Replaced 2 wall heaters at well2.
13. Replaced chlorine injection line at well 2.
14. Ordered a new truck for the Water Department.
15. Inspected and recorded the relocation and removal of meter pits and sewer laterals on Whistling duck Dr.
16. Had Rick replace starter on water dept. truck.
17. Had a meeting with Tidewater management and Town manager.
18. Registered public works personnel for the DRWA Conference in 2/17.
19. Took flagger recertification course.
20. USGS was here to install and update their equipment at well 2.
21. Had the Heritage Shores water tower serviced after a threaded pipe came apart inside the tower and caused a leak. The water tower was taken out of service and the proper authorities were contacted. It was repaired and back in-service in 2 days.



Scott Kimball, Superintendent
Water Department