



WATER DEPARTMENT MARCH 2017 MONTHLY REPORT

<u>Water Supplied this month</u>	5,309,100 gallons
<u>Average Daily Water Supplied</u>	171,261 gallons
<u>Water produced Y.T.D</u>	15,511,100 gallons

Water and Sewer Inspections

31 Waterside Dr.
37 Waterside Dr.
30 Champions Dr.
25 Royal view Dr.
406 Laws st.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

29 Waterside Dr. – 2 meters/ 2 mxu
37 Waterside Dr. – 2 meters/ 2 mxu
14 Amanda teal Dr. – 1 meter
9111 Antique Alley – 1 meter/1 mxu
31 Waterside Dr. – 2 meters/2 mxu
30 Champions dr. – 2 meters/ 2 mxu
115 Waterside Dr. – 2 meters/2 mxu
25 Royal view Dr. – 2 meters/2mxu
9 Legends Way – 2 meters/2 mxu

Final Readings

109 Whistling duck Dr.
39 Waterside Dr.
41 Waterside dr.
510 S. Cannon St.
26 Ruddy duck Dr.
101 Edgewood St.
204 Delaware Ave.
23 Royal view Dr.

C.O. Inspections


39 Waterside Dr.
41 Waterside Dr.

Meters removed : 0

Service Calls : 4

Shut-offs : 3

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Marked various Miss Utility locate tickets.
7. Helped Rick with banners in town.
8. Inspected valves and hydrants on Harlequin Loop.
9. Repaired busted/hit service line on champions Dr.
10. Repaired busted/ hit service line on Royal view Dr.
11. Helped Rick w/ taking down police sign at police department.
12. Helped fix thio sulphate tank at WWTP.
13. Replaced outside lightbulbs at wells and H.S. water tower.
14. Replaced bad heater at well 2 (bad themostat).
15. Helped Rick paint curb.
16. Help fix float at WWTP.
17. Did inventory w/ Scott W.
18. Counted new hydrants at H.S. phase 3.
19. Met w/ Randy from Premiere Construction – dialysis center.
20. Helped w/ clarifier at WWTP.
21. Had a meeting w/ Faris from Brookfield.
22. Did FY18 proposed budget.
23. Helped Jerry catch a bat at the Post office.
24. Attended a water wastewater pump station audit seminar in Millsboro.



Scott Kimball, Superintendent
Water Department