



WATER DEPARTMENT MAY 2017 MONTHLY REPORT

<u>Water Supplied this month</u>	8,860,900 gallons
<u>Average Daily Water Supplied</u>	285,835 gallons
<u>Water produced Y.T.D</u>	30,896,600 gallons

Water and Sewer Inspections

Lot# 381 – 81 Whistling duck Dr.
Lot# 527 – 61 Champions Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

18583 Sussex Hwy. – replaced 1 bad mxu
135 Widgeon Way – replaced 1 bad meter
3 Legend's Way – 2 meters/ 2 mxus
20 Amanda teal Dr. – replaced 1 bad meter
81 Whistling duck Dr. – 2 meters/ 2 mxus
61 Champions Dr. – 2 meters/ 2 mxus

Final Readings

77 Whistling Duck Dr.
133 Champions Dr.
300 Laaws St.
31 Waterside Dr.
115 Emily's pintail
3 Champions Dr.
113 Delaware Ave.
91 Emily's pintail
418/420 Market st.

C.O. Inspections

77 Whistling duck Dr.
133 Champions Dr.
3 Champions Dr.

Meters removed : 1

Elliot Dr.

Service Calls : 11

Shut-offs : 5

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Marked various Miss Utility locate tickets.
7. Continuing to collect fire hydrant data and numbering.
8. Flushing fire hydrants and collecting chemical readings.
9. Mowed grass, weed wacked, and sprayed weeds at wells, lift station, and water tower.
10. L&B Water delivered water meters.
11. Repaired leak on water softener at well 6.
12. Completed inventory list.
13. Had transfer switch repaired at well 5 by Fidelity.
14. Had saddle clamp at Gene's auto repaired by Hopkins Construction.
15. Repaired diaphragm on soda ash pump at well 6 and cleaned flowmeter.
16. Helped Rick with setting up water tank on utility trailer.
17. Watched installation of new sewer lines on Waterside Dr.



Scott Kimball, Superintendent
Water Department