



## WATER DEPARTMENT JUNE 2017 MONTHLY REPORT

<u>Water Supplied this month</u>	11,290,700 gallons
<u>Average Daily Water Supplied</u>	376,357 gallons
<u>Water produced Y.T.D</u>	42,187,300 gallons

### Water and Sewer Inspections

Lot# 677 – 32 Waterside Dr.  
Lot# 563 - 135 Champions Dr.  
Lot# - 721 – 144 Waterside Dr.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

17 Oak St. – 1 meter – replace bad meter  
201 Market St. – 1 meter/1 mxu  
32 Waterside dr. – 2 meters /2 mxu  
135 Champions dr. – 2 meters/2 mxu  
604 N. Cannon St.- 1 mxu – damaged  
35 Church St. – 1 meter/1 mxu  
8 Amanda teal – 1 meter – replace bad meter  
109 N. Main St. – 1 meter/1 mxu

### Final Readings

109 N. Main St.  
212 First St.  
109 N. Cannon St.  
30 Champions Dr.  
14 Amanda teal Dr.  
79 Whistling duck Dr.  
106 N. Main St.  
81 Whistling duck Dr.

### C.O. Inspections

79 Whistling duck Dr.  
2 Blue heron Ct.  
81 Whistling duck Dr.

### Meters removed : 1

111 N. Cannon St.

### Service Calls : 10

### Shut-offs : 2

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Marked various Miss Utility locate tickets.
7. Continuing to collect fire hydrant data and numbering.
8. Flushing fire hydrants and collecting chemical readings and flow data.
9. Mowed grass, weed wacked, and sprayed weeds at wells, lift station, and water tower.
10. Roberto from USGS came to service their equipment at Well 2.
11. Supplied DBF with well production data and permit forms for Allocations.
12. Inspected new meter pits being installed by Gaines on Waterside Dr.
13. Took delivery of new Ford F-250 work truck.
14. Repaired broken Cl2 pump at Well 6.
15. CCR report completed, given to town hall to be put in newsletter, mailed to proper State agencies and places in various public places.
16. Scott W. and I helped with William's St. storm drain project.
17. Got title work done for new work truck.
18. Joe from American Darling put on a hydrant class for our Public Works departments.
19. Mounted tool boxes on new truck.
20. Helped Jeff get keys out of storm drain for a resident on Emily pintail.
21. Watered plant barrels on Market St. several times
22. Did a demonstration of our hose monster for Scott from Lewes Water Dept.
23. Teaching Scott W. how to flow test hydrants.
24. Had inspections done on the 3 generators at the wells.
25. Scott W. and I rebuilt the stand for the watering barrels.
26. Repaired broken Cl2 pump at well 2.
27. Went to Cambridge Md. To pick up chemicals for the wells.



---

Scott Kimball, Superintendent  
Water Department