



## WATER DEPARTMENT AUGUST 2017 MONTHLY REPORT

<b><u>Water Supplied this month</u></b>	10,690,300 gallons
<b><u>Average Daily Water Supplied</u></b>	344,848 gallons
<b><u>Water produced Y.T.D</u></b>	66,048,200 gallons
<b><u>Peak Flow</u></b> – 8/2/17 – 496,700 gallons	

### **Water and Sewer Inspections**

Lot# 714 - 128 Waterside Dr.  
Lot# 502 – 11 Champions Dr.  
Lot# 518 – 43 Champions Dr.  
Lot# 598 – 44 Champions Dr.  
Lot# 599 – 46 Champions Dr.

### **Sewer Extension Inspections**

None this month

### **New Water Meters and MXU's Installed**

22 Waterside Dr. – 2 meters/2 mxu  
128 Waterside Dr. – 2 meters/2 mxu  
34 Waterside Dr. – 2 meters/2 mxu  
11 Champions Dr. – 2 meters/ 2 mxu  
43 Champions Dr – 2 meters/2 mxu  
44 Champions Dr. – 2 meters/ 2 mxu  
69 Emily's pintail Dr. – 1 meter

### **Final Readings**

40 Whistling duck Dr.  
135 Champions Dr.  
19 Waterside Dr.  
14 Champions Dr.  
5 Waterside Dr.  
61 Champions Dr.  
63 Emily's pintail Dr.  
81 Emily's pintail Dr.  
100 Emily's pintail Dr.  
106 S. Main St  
20 Champions Dr.  
1 Amanda teal Dr.

### **C.O. Inspections**


19 Waterside Dr.  
5 Waterside Dr.  
61 Champions Dr.

**Meters removed : 0**

**Service Calls : 6**

**Shut-offs : 0**

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Marked various Miss Utility locate tickets.
7. Mowed grass, weed wacked, and sprayed weeds at wells, lift station, and water tower.
8. Supplied DBF with more well production data for Allocations permit.
9. Repaired water service line on Lot#640, hit by contractor.
10. Attended heat stress training at Town hall.
11. USGS here to calibrate their equipment and to take water samples.
12. Gathered information or Heather – mini storage engineering firm.
13. Helped Jeff with manhole at Heritage Shores.
14. Helped Rick remove sign on S. Main St.
15. Helped Rick with pot hole patching and branch removal.
16. Worked on fire hydrant inventory list.
17. Spoke with John McGee (DBF) about changing the town standards for new meter pits.
18. Met with Bob Johns (Ferguson) to review cut sheets for new meter pits.
19. Helped Rick with parking blocks at Town hall.
20. Took over Miss Utility tickets from Jeff.
21. Took over tier II reporting of hazardous chemicals from Jeff.
22. Attended air valve class at DRWA.
23. Repaired pH meter at Well 5.
24. Contacted JR (Tieder) to change call list for alarms on SCADA.
25. Met with Faris ( Brookfield) about H.S. Phase II completion/ repair updates.
26. Met with George & Lynch guys doing valve/ valve box repairs.
27. Repaired fluoride pump at well 2.
28. Attended workshop to give information on meter reading equipment upgrade.
29. Scott Walls water dept. assistant resigned to take a job in another town.



---

Scott Kimball, Superintendent  
Water Department