



TOWN OF BRIDGEVILLE

WWTP Monthly Report for September, 2017

Date: October 4, 2017

FLOW REPORT

BRIDGEVILLE		GREENWOOD
359,000 9/06/17 9/7/17	MAXIUM	72,249
279,000 GPD GPD	AVERAGE	62,048
8,370,000 GAL GAL	TOTAL	1,861,436

TOTAL COMBINED FLOWS = 10,231,436

TOTAL COMBINED AVERAGE = 341,048

GREENWOOD'S PERCENTAGE COMBINED FLOW = 18.2%

NPDES PERMIT REPORT

TOTAL DAYS OF STREAM DISCHARGE = 0

AVERAGE DAILY FLOW TO STREAM DISCHARGE = 0

TOTAL NPDES PERMIT VIOLATIONS = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS OF SPRAY DISCHARGE TO POND = 30

AVG. DAILY FLOW TO SPRAY DISCHARGE TO POND = 279,000

TOYAL DAYS SPRAY IRRIGATED TO FIELDS = 14

TOTAL SPRAY IRRAGATED FOR MONTH TO FIELDS = 8,370,000

TOTAL SPRAY IRRAGATION VIOLATIONS = 0

SUPERINTEDEDENT'S REPORT

9/25/17 – ASSUMED DUTIES AS SUPERINTEDEDENT

**9/27/17 - COMPLETED AND SUBMITTED SPRAY DMR TO DNREC, EDMR
ALSO SUBMITTED TO DNREC**

RESPECTFULLY SUBMITTED,

PATRICK J. RANKIN

WASTEWATER SUPERINTEDEDENT