



WATER DEPARTMENT NOVEMBER 2017 MONTHLY REPORT

<u>Water Supplied this month</u>	6,034,100 gallons
<u>Average Daily Water Supplied</u>	201,137 gallons
<u>Water produced Y.T.D</u>	91,691,400 gallons
<u>Peak Flow</u> – 11/2/17 – 254,700 gallons	

Water and Sewer Inspections

Lot# 673 - 24 Waterside Dr.
Lot# 597 – 42 Champions Dr.
Lot# 501 – 9 Champions Dr.
15 Church St.
17 Church St.
401 Cedar St. water only

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

24 Waterside Dr. – 2 meters/2 mxu
42 Champions Dr. – 2 meters/2 mxu
15 Church St. – 1 meter/ 1 mxu
17 Church St. – 1 meter/ 1 mxu
69 Whistling duck Dr. – 2 mxus
84 Whistling duck Dr. – 2 mxus
99 Emily Pintail Dr. – 1 meter
116 Widgeon Way – 2 mxus
21 Champions Dr. – 1 mxu
408 S. Main St. – 1 meter
137 Champions Dr. – 1 meter
104 Wills Island – 1 meter

Final Readings

111 Walnut St.
85 Whistling duck Dr.
11 Waterside Dr
4 Blue Heron Ct.
401 Market St.
46 Champions Dr.
80 Emily Pintail Dr.
3 Blue Heron Ct.
10 Amanda Teal Dr.
101 Emily Pintail Dr.
44 Champions Dr.
20 Waterside Dr.

C.O. Inspections

85 Whistling duck Dr.
11 Waterside Dr.
46 Champions Dr.

Meters removed : 0

Service Calls : 29

Shut-offs : 5

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Marked various Miss Utility locate tickets.
7. USDS here to work on their equipment.
8. Fidelity fixed fuel line on generator at well 6.
9. Flushed fire hydrants.
10. Had meeting with Raush, Brookfield, DBF, and other town personnel about phase 4A.
11. Had fire extinguishers inspected.
12. Scheduled meeting with L&B for training on new meter equipment.
13. Had alarm contact information changed on SCADA.
14. Collected water data for Town manager and Wastewater Dept.
15. Salisbury Door repaired door at well 6.
16. Ordered back pressure valve for well 6.
17. Scheduled annual water tower maintenance for December 2017.



Scott Kimball, Superintendent
Water Department