



TOWN OF BRIDGEVILLE

WWTP Monthly Report for November, 2017

Date: December 5, 2017

Superintendents Report

- 1. All fire extinguishers were serviced**
- 2. Got price quotes for roof repair**
- 3. Exhaust fan out of service – on track to fixed in December**
- 4. Obtained DSWA permit to haul bio-solids to landfill**
- 5. Phil Mowbray attended DEFIT**
- 6. Getting quotes for hauling bio-solids**

Respectfully ,

Patrick J. Rankin

Wastewater Superintendent

**TOWN OF BRIDGEVILLE
 WWTP MONTHLY REPORT NOVEMBER, 2017
 DATE: DECEMBER 5, 2017**

BRIDGEVILLE	MAXIMUM AVERAGE TOTAL	GREENWOOD
406,000		65,000 WBHS
328,200		62,108
9,846,000		1,863,241
TOTAL COMBINED	11,709,241	TOTAL AVG. 390,308
GREENWOOD'S	PERCENTAGE FLOW	18.92%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY FLOW TO STREAM = 0

TOTAL STREAM DISCHARGE = 0

NPDES VIOLATIONS = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO POND = 30

AVERAGE DAILY FLOW TO POND = 328,200

TOTAL FLOW DISCHARGE TO POND = 9,846,000

TOTAL DAYS SPRAY IRRIGATED = 8

TOTAL GALLONS SPRAYED ON FIELD = 4,631,000

TOTAL SPRAY DISCHARGE VIOLATIONS = 0