



## WATER DEPARTMENT MARCH 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	5,866,000 gallons
<u>Average Daily Water Supplied</u>	189,226 gallons
<u>Water produced Y.T.D</u>	17,886,600 gallons

### Water and Sewer Inspections

LOT# 634 – 68 Champions Dr.  
LOT# 639 – 78 Champions Dr.  
6 Church St.  
404 Cedar St.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

68 Champions Dr. – 2 meters/ 2 mxu  
6 Church St. – 1 meter/1 mxu  
33 Whistling duck – house – 1 meter  
202 Delaware Ave. - 1 mxu  
107 Walnut st. – 1 mxu  
111 Emily pintail – Irr. – 1 mxu  
113 Emily pintail – Irr. – 1 mxu  
105 Whistling duck – house – 1 meter  
109 Whistling duck – Irr. – 1 meter

### Final Readings

76 Champions Dr.  
65 Emily's pintail Dr.  
54 Champions Dr.  
90 Champions Dr.  
61 Ruddy duck Dr.  
107 Emily's pintail Dr.

### C.O. Inspections

42 Champions Dr.  
54 Champions Dr.  
72 Champions Dr.  
74 Champions Dr.  
76 Champions Dr.  
32 Royal view Dr.

**Meters removed : 0**

**Service Calls : 17**

**Shut-offs : 5**

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Helped Rick with sign at O.A.Newtons.
8. Learned how to start spray rigs with Patrick.
9. Ordered new meter for the carwash.
10. Had 3 water lines at the WWTP repaired by Schrock.
11. Had broken service line in road on Delaware Ave. repaired by Schrock.
12. Had 10" water main on Market St. repaired by Schrock.
13. Took and passed recertification exam for ASSE backflow tester.
14. Removed 2<sup>nd</sup> meter pit at 6 Church St.
15. Went over application for the Water Dept. position.
16. Talked to USG about tower maintenance, still waiting on them to respond.
17. Attended Phase 4 meetings at Town Hall.
18. Set up and conducted interviews with applicants and town staff.
19. Ordered new flow switch for well 6.
20. Installed new Stenner chemical pump at well 2, to try out.
21. Had meeting with Connie from Fidelity about Generator maintenance contract.
22. Checked backed up sewer complaint at 703 N. Cannon St.
23. Set up hydrant meter rental and water usage with Mumford and Miller Construction.
24. Sent in renewal paperwork for AWWA and NRWA memberships.



---

Scott Kimball, Superintendent  
Water Department