



## WATER DEPARTMENT APRIL 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	7,068,600 gallons
<u>Average Daily Water Supplied</u>	235,620 gallons
<u>Water produced Y.T.D</u>	24,955,200 gallons

### Water and Sewer Inspections

LOT# 541 – 89 Champions Dr.  
LOT# 629 – 58 Champions Dr.  
LOT# 377 – 89 Whistling duck Dr.  
LOT# - 648 – 17 Waterside DR.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

78 Champions Dr. – 2 meters/ 2 mxu  
89 Whistling duck – 2 meters/ 2 mxu  
17 Waterside Dr. – 2 meters/2 mxu  
58 Champions Dr. – 2 meters/ 2 mxu  
14 Amanda teal Dr. – 1 meter

### Final Readings

141 Champions Dr.  
78 Champions Dr.  
90 Champions Dr.  
36 Ruddy duck Dr.  
116 Emily's pintail Dr.  
14 Amanda teal Dr.  
114 Market St.  
22 White Pelican Ct.  
78 Champions Dr.  
85 Emily's pintail Dr.  
109 Elliot Dr.  
102 Jacobs St.

### C.O. Inspections


78 Champions Dr.  
90 Champions Dr.

Meters removed : 0

Service Calls : 15

Shut-offs : 9

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Attended Phase 4 meetings at Town Hall.
8. Got information from Weston Solutions about PFC testing.
9. Turned in CCR paperwork to Sherri at DRWA.
10. Did FY19 proposed budget.
11. Replaced batteries in pallet jack at well 6.
12. Replaced leaking flow switch at well 6.
13. Purchased new work carts for wells 2,5 and 6.
14. Purchased new PPE for the wells and work trucks.
15. Tried to find leak on Elm St. with Bob from DRWA.
16. Hired Hilbert Allen Smith as new public works helper.
17. Repaired service line brake on Market St. ( hit by back hoe)
18. Repaired Cl2 at well 5.
19. Repaired fluoride injection fitting at well 5.
20. USGS here to calibrate their equipment in wellk 2.
21. Contacted Tieder Electric about SCADA antenna , still waiting for a reply.
22. Reviewed Tidewater interconnection contract.
23. Shut off Pictsweet fire line for repairs in their building.
24. Ordered new ¾" RPZ backflow preventer for well 2.
25. Took Heritage Shores water tower out of service to have pressure washed and repainted.



---

Scott Kimball, Superintendent  
Water Department