



WATER DEPARTMENT MAY 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	9,694,700 gallons
<u>Average Daily Water Supplied</u>	312,732 gallons
<u>Water produced Y.T.D</u>	34,649,900 gallons

Water and Sewer Inspections

LOT# - 648 – 17 Waterside DR.
401 Market St.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

89 Champions Dr. – 2 meters/ 2 mxu
21 Waterside Dr. – 2 meters/2 mxu
128 waterside Dr. – 2 mxu
68 Whistling duck Dr. – Irr. -1 meter
107 Wills Isl. – Irr. – 1 meter
4 Amanda teal Dr. – Irr. – 1 meter
106 Widgeon way – Irr. – 1 meter
418 Market St. – 1 meter/ 1 mxu

Final Readings

114 widgeon Way
102 Jacobs St.
311 Jacobs St.
59 Whistling duck Dr.
108 Whistling duck Dr.
34 Canvasback Dr.

C.O. Inspections

None this month

Meters removed : 3

115 Sussex Ave.
418 Market St.
420 Market St.

Service Calls : 20

Shut-offs : 0

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Got another quote from Weston Solutions about PFC testing.
8. Submitted CCR report to O.D.W. and State Advocate Office.
9. Had H. S. water tower pressure washed and painted.
10. Put H.S. water tower back in service.
11. Attended budget work shop.
12. Installed new 3/4" RPZ in well 2.
13. Fixed hose monster pressure gauge.
14. Discussed back flow preventer issues with Town manager.
15. Sent autogun to Senus for repair.
16. Registered Allen for Water operator exam.
17. Attended Asset management class at DRWA.
18. Attended Bob Slater's retirement party at DRWA.
19. Had door handle at well 6 repaired broken by Intercostal .
20. Started counting SR II meters in service at H.S.
21. Had F-350 repaired. Front end alignment, brakes, tires, and oil change.
22. Set up and take down of Memorial Day Service.



Scott Kimball, Superintendent
Water Department