



## **TOWN OF BRIDGEVILLE**

**WWTP Monthly Report for June, 2018**

**Date: July 3, 2017**

**Superintendents Report**

- 1. All E.P.A and DNREC reports are being completed**
- 2. Raw pump A is repaired waiting to install when line is cleared**
- 3. Comminuter A still on order waiting for it to come in**
- 4. Added sand to drying beds**

**Respectfully,**

**Patrick J. Rankin**

**Wastewater Superintendent**

A handwritten signature in black ink that reads 'Patrick J. Rankin'.

# TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT JUNE, 2018

**DATE: JULY 3, 2018**

BRIDGEVILLE		GREENWOOD
437,000	MAXIMUM AVERAGE TOTAL	79,466
329,000		71,770
9,859,000		2,153,086

TOTAL COMBINED FLOW = 12,012,086  
GREENWOOD'S PERCENTAGE OF FLOW = 21.84%

## NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

## SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 329,000

TOTAL FLOW DISCHARGE TO LAGOON = 9,859,000

TOTAL DAYS IRRIGATED = 25

TOTAL GALLONS SPRAYED ON FIELD = 16,839,000

TOAL SPRAY VIOLATIONS = 0