



## WATER DEPARTMENT JULY 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	14,654,800 gallons
<u>Average Daily Water Supplied</u>	472,736 gallons
<u>Water produced Y.T.D</u>	59,729,100 gallons

### Water and Sewer Inspections

LOT# - 556 – 121 Champions DR.  
LOT# - 528 – 63 Champions Dr.  
Water only – 400 Sussex st. Ext.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

63 Champions Dr. – 2 meters/ 2 mxu  
54 Canvasback Cr. – 1 meter  
5 Champions dr. – 1 meter  
37 Harlequin Loop – 2 mxu  
101 Wills Island – 1mxu  
103 Wills Island – 1  
400 Sussex St. ext. – 1 meter/ 1mxu

### Final Readings

307 Edgewood St.  
5 Harlequin loop  
53 Whistling duck Dr.  
56 Champions dr.  
6 Elm St.

### C.O. Inspections

89 Champions Dr.  
56 Champions Dr.  
38 Royal view Dr.

Meters removed : 0

Service Calls : 18

Shut-offs : 2

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did numerus Miss Utility locate tickets.
7. USGS calibrated their equipment at well 2.
8. Had leak on Elm St. repaired.
9. Had leak at 59/61 Emily pintail repaired.
10. Trained Allen at wells.
11. Flushed and flow tested fire hydrants.
12. Spoke with John at Tidewater about having 4 meters replaced.
13. Put out copies of CCR report in public places.
14. Spoke with USG, got safety data sheets for interior paint for water tower.
15. Attended Tazz's meeting to discuss backflow preventers.
16. Ordered and received new leak detector.
17. Did Allen's 90 day evaluation.
18. Had meeting with Joe Hughs about vulnerability assessment review.
19. Had Tieder electric here to check SCADA issues.
20. Ordered and handed out PPE equipment.
21. Contacted O.D.W. about water tower project and received approval letter.
22. Mailed letters to residents within 1000 ft. of the in town water tower for up coming project.
23. Bill from DRWA trained me on new leak detector.
24. Fixed chlorine pump at well 2.
25. Received new autogun.(meter reading equipment)



---

Scott Kimball, Superintendent  
Water Department