



TOWN OF BRIDGEVILLE

WWTP Monthly Report for July, 2018

Date: August 7, 2017

Superintendents Report

- 1. All E.P.A and DNREC reports are being completed**
- 2. Force man leak Hopkin's Construction Repaired**
- 3. All raw influent pumps are in service now**
- 4. Installed Pressure Transducer to replace mercury switches for raw pump**

Respectfully,

Patrick J. Rankin

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT July, 2018

DATE: August 7, 2018

BRIDGEVILLE		GREENWOOD
422,000	MAXIMUM AVERAGE TOTAL	59,609
286,000		55,448
8,872,000		1,718,895

TOTAL COMBINED FLOW = 10,590,895
GREENWOOD'S PERCENTAGE OF FLOW = 19.37%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 5.0 hours

AVERAGE DAILY STREAM FLOW = 12,333

TOTAL STREAM DISCHARGE = 61,655

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 31

AVERAGE DAILY FLOW TO LAGOON = 286,000

TOTAL FLOW DISCHARGE TO LAGOON = 8,872,000

TOTAL DAYS IRRIGATED = 23

TOTAL GALLONS SPRAYED ON FIELD = 12,529,000

TOAL SPRAY VIOLATIONS = 0