



WATER DEPARTMENT AUGUST 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	13,220,300 gallons
<u>Average Daily Water Supplied</u>	426,461 gallons
<u>Water produced Y.T.D</u>	72,949,400 gallons

Water and Sewer Inspections

LOT# - 384 – 75 Whistling duck Dr.
LOT# - 646 – 13 Waterside Dr.
LOT#- 652 – 25 Waterside Dr.
Sewer only – 13 Oak St.
Water only – 213 S. Main St.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

121 Champions Dr. – 2 meters/ 2 mxu
13 Waterside Dr. – 2 meters/2 mxu
25 Waterside Dr. – 2 meters/2 mxu
59 Emily pintail Dr. 1 meter
24 White Pelican Cr. – 1 meter
46 Snowy Egret Cr. – 1 meter
29 Amanda Teal Dr. – 1 meter
47 Canvasback Cr. – 2 meters

Final Readings

Jimmy's Grille
Jimmy's Banquet Hall
16 Gadwall Cr.
402 S. Main St.
63 Champions Dr.
6 Waterside Dr.
59 Canvasback Cr.
121 Champions dr.
23589 Link side Dr.
27 Ruddy duck Dr.

C.O. Inspections

63 Champions Dr.
6 Waterside Dr.

Meters removed : 0

Service Calls : 30

Shut-offs : 10

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did numerus Miss Utility locate tickets.
7. Roberto from USGS calibrated their equipment at well 2.
8. Had leak on Elm St. repaired.
9. Continue to train Allen at wells.
10. Flushed and flow tested fire hydrants.
11. Attended Phase 4C meeting at Town Hall.
12. Had Bi- annual maintenance done on generators at wells 2-5-6.
 - Well 2 needs a new radiator has a hole in it and needs fuel filtered/ cleaned.\
13. Had temporary antenna installed at WWTP for SCADA system by Tieder.
14. Had antenna removed from water tower for painting by Tieder.
15. Drained 125K water tower for painting and maintenance to start 8/13/18.
16. Water tower painting and maintenance cancelled 8/9/18 without notice
17. Put 125K water tower back in service, with O.D.W. permission on 8/9/18.
18. Did Allen's second evaluation.
19. Showed Jesse how to do wells 2 and 5.
20. Ordered new phone for the Public works Dept.
21. Ordered testing supplies for the wells.
22. Rented fire hydrant meter to Recon Construction.
23. Filled pot holes with Phillip
24. Had several meetings with Jesse.

The water tower painting and maintenance has been postponed until 2019, it was rescheduled without my/our notice. I have spoken with my contact at the company and can't get a straight answer. I will be having a meeting with Town Manager to discuss further actions.



Scott Kimball, Superintendent
Water Department