



TOWN OF BRIDGEVILLE

WWTP Monthly Report for September, 2018

Date: October 3 , 2018

Superintendents Report

- 1. All E.P.A and DNREC reports are being completed**
- 2. Only irrigated 6 days, Farmer harvesting crops**
- 3. Lagoon Level as of September 30, 2018 was 5.5'ft**
- 4. Getting Quotes to fix sinking manholes on the corners of Market and Williams Street and Market and North Cannon Street. Hope to have them fixed by the end of October.**

Respectfully,

Patrick J. Rankin

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT
SEPTEMBER, 2018
DATE: OCTOBER 3, 2018

BRIDGEVILLE		GREENWOOD
430,000	MAXIMUM	67,062
288,000	AVERAGE	66,503
8,637,000	TOTAL	1,995,096

TOTAL COMBINED FLOW = 10,632,096
GREENWOOD'S PERCENTAGE OF FLOW = 23.1%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 288,000

TOTAL FLOW DISCHARGE TO LAGOON = 8,637,000

TOTAL DAYS IRRIGATED = 6

TOTAL GALLONS SPRAYED ON FIELD = 1,891,000

TOAL SPRAY VIOLATIONS = 0