



## **TOWN OF BRIDGEVILLE**

**WWTP Monthly Report for October, 2018**

**Date: November 9, 2018**

**Superintendents Report**

- 1. All E.P.A and DNREC reports are being completed**
- 2. Manhole repair on Market St. and Williams St finished**
- 3. Manhole on Market St. and S. Cannon Scheduled to be repaired**
- 4.**

**Respectfully,**

**Patrick J. Rankin**

**Wastewater Superintendent**

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large initial "P".

# TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

**OCTOBER, 2018**

**DATE: NOVEMBER 9, 2018**

BRIDGEVILLE		GREENWOOD
421,000	MAXIMUM AVERAGE TOTAL	62,524
270,000		61,874
8,375,000		1,918,059

**TOTAL COMBINED FLOW = 10,293,059**  
**GREENWOOD'S PERCENTAGE OF FLOW = 22.9%**

## NPDES PERMIT REPORT

**TOTAL DAYS STREAM DISCHARGE = 0**

**AVERAGE DAILY STREAM FLOW = 0**

**TOTAL STREAM DISCHARGE = 0**

## SPRAY IRRIGATION PERMIT REPORT

**TOTAL DAYS DISCHARGE TO LAGOON = 31**

**AVERAGE DAILY FLOW TO LAGOON = 270,000**

**TOTAL FLOW DISCHARGE TO LAGOON = 8,375,000**

**TOTAL DAYS IRRIGATED = 12**

**TOTAL GALLONS SPRAYED ON FIELD = 6,283,000**

**TOAL SPRAY VIOLATIONS = 0**