



WATER DEPARTMENT OCTOBER 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	6,209,500 gallons
<u>Average Daily Water Supplied</u>	200,306 gallons
<u>Water produced Y.T.D</u>	88,619,500 gallons

Water and Sewer Inspections

LOT# - 669 – 16 Waterside Dr.
LOT#- 557 – 123 Champions Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

102 Edgewood St. – 1 meter
15 Gadwall Cr. – 1 meter
62 Emily pintail Dr. – 1 meter

Final Readings

78 Whistling duck Dr.
58 Whistling duck Dr.
140 Waterside Dr.
27 Waterside Dr.
20 Waterside Dr.
108 Emily pintail Dr.
73 Whistling duck Dr.
23595 Link side Dr.

C.O. Inspections

75 Whistling duck Dr.
15 Waterside Dr.
140 Waterside Dr.

Meters removed : 0

Service Calls : 12

Shut-offs : 6

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did numerus Miss Utility locate tickets.
7. Flushed and flow tested fire hydrants.
8. Attended Miss Utility training at the Cheer Center in Georgetown.
9. Trained Allen in the wells.
10. Trained Allen on hydrant flushing and flow testing.
11. Attended DRWA Expo in Milford.
12. Attended DRWA training at KCWWTP.
13. Put out and picked up water equipment fr Apple Scrapple Festival.
14. Worked Apple Scrapple Festival.\
15. Installed new toilet at Public Works building.
16. Picked up and returned light towers ti Greenwood.
17. Rebuilt Cl2 pump at well 2.
18. Old Schonstedt locator died (28 years old)
19. Researching info on new locator.
20. Labeled hydrants on map.
21. Worked on hydrant logbook.
22. Installed new hydrant flags.
23. Had fuel and fuel tank cleaned on generator at well 2.
24. Had radiator replaced on generator at well 2.
25. Had a power surge at well 2, damaged control panels on well and generator. 10/22/18
26. Had control panel for generator replaced.
27. Ordered control panel for well.
28. Contacted Allied Trailers to get price to move construction trailer from H.S.



Scott Kimball, Superintendent
Water Department