



WATER DEPARTMENT NOVEMBER 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	5,899,500 gallons
<u>Average Daily Water Supplied</u>	196,653 gallons
<u>Water produced Y.T.D</u>	94,519,100 gallons

Water and Sewer Inspections

LOT# - 668 – 14 Waterside Dr.
LOT#- 553 – 115 Champions Dr.
LOT# - 378 – 87 Whistling duck Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

14 Waterside Dr. – 2 meters/ 2 mxu
16 Waterside Dr. – 2 meters/ 2 mxu
123 Champions Dr. – 2 meters/ 2 mxu
115 Champions Dr. – 2 meters/ 2 mxu
87 Whistling duck Dr. – 2 meters/ 2 mxu
98 Whistling duck Dr. – 1 meter
14 Gadwall Cr. – 1 meter
20 Gadwall Cr. – 1 meter
34 Royal view Dr. – 1 meter
22 Canvasback Dr. – 1 meter

Final Readings

142 Waterside Dr.

C.O. Inspections

87 Whistling duck Dr.
15 Waterside Dr.
16 Waterside Dr.

Meters removed : 0

Service Calls : 19

Shut-offs : 2

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did numerus Miss Utility locate tickets.
7. Flushed and flow tested fire hydrants.
8. Trained Allen in the wells.
9. Trained Allen on hydrant flushing and flow testing.
10. Had SCADA screen replaced at well 2 and at WWTP.
11. Contacted contractors for quote to move trailer from H.S.
12. Bought new battery for Neptune Reader.
13. Replaced Cl2 pump at well 2.
14. Repaired soda ash pump at well 6.
15. Ordered new diaphragms for soda ash pump at well 6.
16. Bought new pipe and cable locator and metal detector.
17. Realigned gate at H.S. water tower.
18. Prepared dead end hydrant list for Town manager.
19. USGS here to calibrate their equipment.
20. Had block heater replaced at well 5.
21. Checked hydrant E-13, H.S. pool area. No Leak



Scott Kimball, Superintendent
Water Department