



TOWN OF BRIDGEVILLE

WWTP Monthly Report for December, 2018

Date: January 9, 2017

Superintendents Report

- 1. All E.P.A and DNREC reports are being completed**
- 2. Annual Spray Irrigation Inspection**
- 3. Manhole on Market St, South Cannon Fixed**
- 4. Adjusted Rig #1 from spraying on ponding areas in field**
- 5. Working on New NPDES Permit**
- 6. Working on Annual Report for DNREC**

Respectfully,

Patrick J. Rankin

Wastewater Superintendent

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

DECEMBER, 2018

DATE: JANUARY 9, 2018

BRIDGEVILLE		GREENWOOD
444,000	MAXIMUM AVERAGE TOTAL	68,174
312,167		64,296
9,365,000		1,993,167

TOTAL COMBINED FLOW = 11,358,167
GREENWOOD'S PERCENTAGE OF FLOW = 21.28%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 312,167

TOTAL FLOW DISCHARGE TO LAGOON = 9,365,000

TOTAL DAYS IRRIGATED = 22

TOTAL GALLONS SPRAYED ON FIELD = 6,122,000

TOAL SPRAY VIOLATIONS = 0