



WATER DEPARTMENT SEPTEMBER 2018 MONTHLY REPORT

<u>Water Supplied this month</u>	9,460,600 gallons
<u>Average Daily Water Supplied</u>	315,353 gallons
<u>Water produced Y.T.D</u>	82,410,000 gallons

Water and Sewer Inspections

LOT# - 647 – 15 Waterside Dr.
LOT#- 720 - 140 Waterside Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

75 Whistling duck – 2 meters/ 2 mxu
140 Waterside Dr. – 2 meters/2 mxu
15 Waterside Dr. – 2 meters/2 mxu
54 Emily pintail Dr. 1 meter
18 Amanda teal Dr. – 1 mxu
38 Snowy Egret Cr. – 1 meter
20 Amanda Teal Dr. – 1 meter/ 1 mxu
3 Canvasback Cr. – 1 meters
207 Market St. – 1 meter

Final Readings

94 Emily pintail Dr.
108 Elliott Dr.
20 Gadwall Cr.
25 Waterside Dr.
89 Champions Dr.
111 Emily pintail Dr.
63 Whistling duck Dr.
121 Champions Dr.

C.O. Inspections

121 Champions Dr.
25 Waterside Dr.
13 Waterside Dr.

Meters removed : 0

Service Calls : 13

Shut-offs : 0

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did numerus Miss Utility locate tickets.
7. Roberto from USGS calibrated their equipment at well 2.
8. Flushed and flow tested fire hydrants.
9. Put in temporary yard hydrant at new police station site.
10. Tieder replaced broken co-ax cable at H.S. lift station, back in service.
11. Tieder replaced battery back up in control panel at WWTP.
12. Took signed maintenance contracts to Fidelity in Seaford.
13. Fidelity replaced battery at well 5.
14. Replaced fluoride injection fitting at well 5.
15. Had meeting with DBF and Veteran Builders about meter pit location at new police station.
16. Ordered and received new 2" meter pit and meter for new police station.
17. Had meeting with Joe Hughs about assets at wells.
18. Had 400 amp fuses replaced at well 6.



Scott Kimball, Superintendent
Water Department