



## WATER DEPARTMENT MARCH 2019 MONTHLY REPORT

<u>Water Supplied this month</u>	5,529,800 gallons
<u>Average Daily Water Supplied</u>	178,381 gallons
<u>Water produced Y.T.D</u>	17,082,300 gallons

### Water and Sewer Inspections

LOT# 635 – 70 Champions Dr.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

75 Champions Dr. - 2 meters/1 mxu  
97 Whistling duck Dr. – 2 meters/1 mxu  
52 Champions Dr. – 2 meters/1 mxu  
70 Champions Dr. – 2 meters/1 mxu  
50 Champions Dr. – 2 meters/1 mxu  
57 Champions Dr. – 2 meters/1 mxu  
118 Waterside Dr. – 2 meters/1 mxu  
13 Oak St. – 1 meter

### Final Readings

97 Whistling duck Dr.  
202 N. Main St.  
75 Champions Dr.  
52 Champions Dr.  
7 Waterside Dr.  
72 Whistling duck Dr.  
102 Walnut St.  
308 Edgewood St.  
8 Ruddy duck Dr.

### C.O. Inspections

97 Whistling Duck Dr.  
75 Champions Dr.  
73 Champions Dr.  
50 Champions Dr.  
52 Champions Dr. – not ready  
117 Champions Dr.

### Meters removed : 1

103 S. Main St.

### Service Calls : 18

### Shut-offs : 6

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Roberto from USGS here to calibrate their equipment.
8. Cleaned and refilled Sodium Fluoride tank at Wells 2 and 5.
9. Collected data for DNREC background check.
10. Finished and mailed permit for water tower painting permit.
11. Found out certified mail to DNREC lost by USPS.
12. Collected data for Tetrattech- doing asset program for the State.
13. Replaced Security lights at wells 2,5, and 6.
14. Fixed leak on chlorine pump at well 6.
15. Had bi-annual maintenance performed on generators at wells 2,5, and 6.
16. Had annual load bank testing performed on generators at wells 2,5, and 6.
17. Had meeting with Public Works and contractors at 400 Sussex St. Ext.
18. Reviewed Coastal Run Apartment plans.
19. Repaired busted meter pit at 13 Oak. St. Ran over.
20. Had security fence installed around well 6.



---

Scott Kimball, Superintendent  
Water Department