



TOWN OF BRIDGEVILLE

WWTP Monthly Report for May, 2019

Date: June 5, 2019

Superintendents Report

- 1. All E.P.A and DNREC reports are being completed**
 - 2. Compliance follow up letter completed and sent in.**
 - 3. Sussex County Vactor crew cleaned out Sonic lift station**
 - 4. Completed Greenwood's First Quarter Billing.**
 - 5. Fidelity Power Systems Replaced fuel lines and coolant hoses and thermostat along with cleaning and putting new coolant in radiator for plant generator.**
 - 6. Phillip Mowbray attended DEFIT meeting in Dover.**
 - 7. A.C Shultes installed new lysimeter.**
 - 8. Replaced battery in sonic lift station generator.**
 - 9. Raw Influent wet well cleaned due to large amount of trash and debris in wet well.**
 - 10. Phillip Mowbray and myself unclogged A and B raw pumps**
 - 11. Phillip Mowbray and myself unjammed Comminuter A.**
-


12. RBC B3 kicked out , call Billbrough Electric to fix had to put bigger overloads on. Seemed to fix problem for now.

13. All preventive maintenance done for the month of May,2019.

Respectfully,

Patrick J. Rankin

Wastewater Superintendent

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large, stylized initial "P".

**TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT MAY,
2019**

DATE: JUNE 5, 2018

BRIDGEVILLE		GREENWOOD
417,000	MAXIMUM AVERAGE TOTAL	72,466
305,000		68,372
9,452,000		2,119,541

TOTAL COMBINED FLOW = 11,571,541
GREENWOOD'S PERCENTAGE OF FLOW = 22.42%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 305,000

TOTAL FLOW DISCHARGE TO LAGOON = 9,452,000

TOTAL DAYS IRRIGATED = 10

TOTAL GALLONS SPRAYED ON FIELD = 5,383,000

TOAL SPRAY VIOLATIONS = 0