



WATER DEPARTMENT MAY 2019 MONTHLY REPORT

<u>Water Supplied this month</u>	8,629,400 gallons
<u>Average Daily Water Supplied</u>	278,3 gallons
<u>Water produced Y.T.D</u>	32,327,800 gallons

Water and Sewer Inspections

LOT# 536 – 79 Champions Dr.
LOT # 592 – 32 Champions Dr.
LOT# 594 – 36 Champions Dr.
LOT# 542 – 91 Champions Dr.
LOT# 544 – 97 Champions Dr.
LOT# 719 – 138 Waterside Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

67 Champions Dr. - 2 meters/1 mxu
79 Champions Dr. – 2meters/1 mxu
91 Champions Dr. – 2 meters/1mxu
97 Champions Dr. – 2 meters/1 mxu
32 Champions Dr. – 2 meters/1mxu
36 Champions Dr. – 2 meters/1 mxu
105 S. Main t. – 1 meter/1mxu
138 Waterside Dr. – 2 meters/1 mxu
3 Ruddy duck Dr. – 1 mxu
Woodbridge School/ ECEC – 1 mxu
22 Ruddy duck Dr. – 1 mxu
6 Gadwall Cr. – 1 meter
116 Emily pintail Dr. – 1 meter
2 Gadwall Cr.-1 meter
11 Amanda teal Dr. – 1 meter
12 Blue Heron Ct. – 1 meter

Final Readings

400 Sussex Ave.
22 Harlequin Loop
118 Waterside Dr.
115 Emily pintail Dr.
42 Ruddy duck Dr.
415 Delaware Ave.

C.O. Inspections

118 Waterside Dr.

Meters removed : 0

Service Calls : 21

Shut-offs : 0

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Did FY20 budget.
8. Had fire hydrant at 53 Whistling duck Dr. moved.
9. Repaired busted service line at 97 Champions Dr.
10. Reviewed Coastal Run 3rd revision.
11. Had fire hydrant at 70 Whistling duck Dr. repaired.
12. Attended budget workshop at Town meeting.
13. Had meetin wit Jason (DBF) about Coastal Run
14. USGS remove equipment and took final sample at well 2.
15. Submitted 2018 annual CCR Report to proper authorities.
16. Contacted SUEZ "Utilities Service Group" about water tower painting.
17. Had meeting with Tetrtech (asset management for DNREC)
18. Flushed fire hydrants.
19. Reviewed Allocation permit submittal and spoke with Rob Duma (DBF)

Got results for PFOS and PFOA sample taken at well 2 on 9/10/18by USGS.

PFOA = 5.1 parts per trillion.

PFOS = < 6.0 parts per trillion – below detection level

EPA health advisory level is 70 parts per trillion combined.

All other are non-detectable.



Scott Kimball, Superintendent

Water Department