



## **TOWN OF BRIDGEVILLE**

**WWTP Monthly Report for July, 2019**

**Date: August 8, 2019, 2019**


**Superintendents Report**

- 1. All E.P.A and DNREC reports are being completed**
  - 2. Plant Generator P.M**
  - 3. RBC A2 chamber pumped out per A.O.C**
  - 4. Greenwood 2<sup>nd</sup> quarter billing done for T.M**
  - 5. Contractor here to inspect for asbestos .**
  - 6. Inspected Monitoring wells.**
  - 7. National HVAC here to service Air conditioners.**
  - 8. Sent test results to Seaford WWTP.**
  - 9. Dominion Air Serviced Air Compressors.**
  - 10. Heritage Shores lift station comm failure have to replace UPS on order.**
  - 11. Did 4 locates for deldot**
  - 12. Found 4 wheeler and cart in lagoon.**
-

**Respectfully,**

**Patrick J. Rankin**

**Wastewater Superintendent**

A handwritten signature in black ink that reads "Patrick J. Rankin". The signature is written in a cursive style with a large, looping initial "P".

**TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT JULY,  
2019**

**DATE: AUGUST 8, 2018**

<b>BRIDGEVILLE</b>		<b>GREENWOOD</b>
<b>331,000</b>	<b>MAXIMUM</b>	<b>58,558</b>
<b>262,600</b>	<b>AVERAGE</b>	<b>59,734</b>
<b>8,141,000</b>	<b>TOTAL</b>	<b>1,796,970</b>

**TOTAL COMBINED FLOW = 9,937,970**  
**GREENWOOD'S PERCENTAGE OF FLOW = 22.07%**

**NPDES PERMIT REPORT**

**TOTAL DAYS STREAM DISCHARGE = 0**

**AVERAGE DAILY STREAM FLOW = 0**

**TOTAL STREAM DISCHARGE = 0**

**SPRAY IRRIGATION PERMIT REPORT**

**TOTAL DAYS DISCHARGE TO LAGOON = 31**

**AVERAGE DAILY FLOW TO LAGOON = 262,600**

**TOTAL FLOW DISCHARGE TO LAGOON = 8,141,000**

**TOTAL DAYS IRRIGATED = 28**

**TOTAL GALLONS SPRAYED ON FIELD = 19,236,000**

**TOAL SPRAY VIOLATIONS = 0**