



WATER DEPARTMENT JULY 2019 MONTHLY REPORT

<u>Water Supplied this month</u>	15,293,100 gallons
<u>Average Daily Water Supplied</u>	493,326 gallons
<u>Water produced Y.T.D - 59% of Allocation</u>	57,756,300 gallons

Water and Sewer Inspections

502 Birch St. St. – sewer only
H.S. Common area – Champions Dr.- water only
H.S. Common area – Waterside Dr. island – water only
H.S. Common area – Waterside Dr. island – water only
H.S. Common area – Waterside Dr. vacant lot – water only

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

6 Harlequin Loop– 1 meter
132 Emily pintail DR.– 1 meter /1 mxu
18 Gadwall Cr. – 2 meters /1 mxu
56 Whistling duck Dr. – 1 meter
130 Emily pintail Dr. – 1 meter/1 mxu

Final Readings

67 Emily pintail Dr.
22 Champions Dr.
53 Ruddy duck Dr.
70 Champions Dr.
36 Champions Dr.
35 Ruddy duck Dr.
130 Widgeon Way
414 Laws St.
107 N. Cannon St.
201 Laws St.
10 Gadwall Cr.

C.O. Inspections

Meters removed : 0

Service Calls : 18

Shut-offs : 5

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Had Tieder electric working on telemetry issues at well 6.
8. Working on inventory replacement costs.
9. Collected and submitted more Allocation information for Rob at DBF.
10. Ordered and picked up Lead and Copper sample kits from Envirocorp.
11. Ordered supplies.
12. Installed NO PARKING sign at well 6 entrance.
13. Restocked supplies at well houses.
14. Fidelity did bi-annual generator maintenance at well 2, 5, and 6.
15. Contacted Keith at O.D.W. about CCR report.
16. Had generators filled with fuel.
17. Brookfield fixing valve boxes and manhole on Champions and H.S. Circle.



Scott Kimball, Superintendent

Water Department