



TOWN OF BRIDGEVILLE

WWTP Monthly Report for September 2019

Date: October 8, 2019

Superintendents Report

- 1. All E.P.A and DNREC reports are being completed**
- 2. All sampling and testing for September are completed**
- 3. Replaced oil seals and bearings in RBC A1 gearbox**
- 4. Replaced sign post at spray field entrance**
- 5. Replaced Recirculation pump face with used one. Old pump face wore a hole through it.**
- 6. Replaced a contactor on second from last tower on Spray Rig #1**
- 7. Monthly Preventive maintenance done**
- 8. Phillip Mowbray attended DEFIT meeting**
- 9. Removed Four Wheeler and Trailer from lagoon.**

Respectfully,

Patrick J. Rankin

A handwritten signature in black ink that reads "Patrick J. Rankin".

TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT
SEPTEMBER
DATE: OCTOBER 8, 2018

BRIDGEVILLE		GREENWOOD
300,000	MAXIMUM AVERAGE TOTAL	56,727
237,300		58,328
7,119,000		1,749,831

TOTAL COMBINED FLOW = 8,868,831
GREENWOOD'S PERCENTAGE OF FLOW = 24.58%

NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 30

AVERAGE DAILY FLOW TO LAGOON = 237,300

TOTAL FLOW DISCHARGE TO LAGOON = 7,119,000

TOTAL DAYS IRRIGATED = 26

TOTAL GALLONS SPRAYED ON FIELD = 7,986,000

TOAL SPRAY VIOLATIONS = 0