



## WATER DEPARTMENT SEPTEMBER 2019 MONTHLY REPORT

<u>Water Supplied this month</u>	11,861,100 gallons
<u>Average Daily Water Supplied</u>	395,370 gallons
<u>Water produced Y.T.D -</u>	81,850,700 gallons

### Water and Sewer Inspections

LOT# 520 – 47 Champions Dr.  
LOT# 531 – 69 Champions Dr.  
LOT# 608 – 1 Green fair Way  
LOT# 641- 3 Waterside Dr.

### Sewer Extension Inspections

None this month

### New Water Meters and MXU's Installed

69 Champions Dr. – 2 meters/1mxu  
47 Champions Dr. – 2 meters/1 mxu  
1 Green fair Way – 2 meters/1mxu  
3 Waterside Dr. – 2 meters/1mxu  
106 Widgeon way – 1 mxu  
8 Ruddy duck Dr. – 1 meter  
40 Whistling duck dr. – 1 meter  
6 Canvasback Dr. – 1 meter  
128 Emily pintail Dr. – 1 meter

### Final Readings

18 Ruddy duck Dr.  
12 Blue heron Ct.  
110 Widgeon Way  
416 Laws st.  
24 Gadwall Cr.  
60 Ruddy duck Dr.  
101 Emily pintail Dr.  
300 S. Main St.

### C.O. Inspections

Meters removed : 0

Service Calls : 14

Shut-offs : 4

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Finished and submitted inventory replacement costs.
8. Collected more data for Rob (DBF) for allocation permit.
9. Completed and submitted lead and copper samples.
10. Received new "Pumpstick" meter pit pump.
11. Completed Lead and Copper sample plan for O.D.W.
12. Working on pole barn quotes, need to advertise for sealed bids.
13. Had meeting with David (LB Water), turned in RMA's.
14. Replaced leaking oil filter on T-1.
15. Repaired well 6 soda ash pump with Rick.
16. Tieder replaced bad HMI at well5.
17. Singed up for endorsement class at DTCC.
18. Plumbed fluoride meter at well 5.
19. Water tower #1 had visual inspection performed by USG.
20. Did JOB review (Sussex Ave).
21. Did review for ministorage (S. Main St.)
22. Attended SCADA class at DRWA.
23. Made revisions and submitted ( water and wastewater sections) to Asset Venerability report to Town Manager.



---

Scott Kimball, Superintendent

Water Department