



WATER DEPARTMENT OCTOBER 2019 MONTHLY REPORT

<u>Water Supplied this month</u>	11,152,600 gallons
<u>Average Daily Water Supplied</u>	359,761 gallons
<u>Water produced Y.T.D -</u>	93,003,300 gallons

Water and Sewer Inspections

LOT# 523 – 53 Champions Dr.
LOT# 665 – 8 Waterside Dr.
LOT# 667 – 12 Waterside Dr.
LOT# 716- 132 Waterside Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

601 N. Cannon St. 1 meter/1 mxu
5 Ruddy duck Dr. – 1 meter
12 Waterside Dr. – 2 meters/1 mxu
132 Waterside Dr. – 2 meters/1 mxu
8 Waterside Dr. – 2meters/1 mxu
53 Champions Dr. – 2 meters/1 mxu
21 Amanda teal Dr. – 1 meter
100 Wills Isl. – 1 meter
117 Whistling duck Dr. – 1 meter

Final Readings

46 Ruddy duck Dr.
65 Champions Dr.
112 N. Cannon St.
205 First St.
31 Amanda teal Dr.
6 Whistling duck Dr.
1 Greenfair Way
48 Whistling duck Dr.

C.O. Inspections

1 Greenfair Way

Meters removed : 0

Service Calls : 35

Shut-offs : 0

1. Water meter readings.
2. Routine samples and readings at wells.
3. Monthly water samples and usage report for the Office of Drinking Water.
4. Performed routine duties and regular maintenance.
5. Meetings with Town Manger.
6. Did various Miss Utility locate tickets.
7. Collected more data for Rob (DBF) for allocation permit.
8. Spoke with Rob Duma at BDF about well data.
9. Replaced diaphragm on back-up soda ash pump at well 6.
10. Replaced diaphragm on main soda ash pump at well6.
11. Ordered new parts for main soda ash pump at well 6.
12. Flushed hydrants for Apple Scrapple festival.
13. Put out and picked up water equipment for Apple Scrapple festival.
14. Helped Rick with Apple Scrapple festival.
15. Ordered 4 new single meter pits for up coming new construction.
16. Tieder replaced bad UPS at well 5, that we just replaced.
17. Talked to area irrigation companies about irrigation winterization.
18. Fixed Cl2 discharge line at well 5.



Scott Kimball, Superintendent

Water Department