



**TOWN OF BRIDGEVILLE**

**WWTP Monthly Report for October 2019**

**Date: November 8, 2019**

**Superintendents Report**

- 1. All E.P.A and DNREC reports are being completed**
- 2. Moved Shed from farm to Public Works**
- 3. Meeting with engineers and contractors at Heritage Shores Pump Station to see what needed to switch over to Sussex County and Seaford Specs**
- 4. Stopped Spraying on field so farmer could harvest crop**
- 5. Sussex County picked up prints and scanned into computer files**
- 6. Phillip Mowbray attended DEFIT**
- 7. All preventive maintenance done**

**Respectfully Submitted,**

A handwritten signature in black ink that reads "Patrick Rankin".

**Patrick Rankin**  
**Wastewater Superintendent**

# TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT

OCTOBER, 2019

DATE: NOVEMBER 8, 2019

BRIDGEVILLE		GREENWOOD
365,000	MAXIMUM	54,830
229,680	AVERAGE	57,767
7,120,000	TOTAL	1,790,784

TOTAL COMBINED FLOW = 8,910,784

GREENWOOD'S PERCENTAGE OF FLOW = 25.15%

## NPDES PERMIT REPORT

TOTAL DAYS STREAM DISCHARGE = 0

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

## SPRAY IRRIGATION PERMIT REPORT

TOTAL DAYS DISCHARGE TO LAGOON = 12

AVERAGE DAILY FLOW TO LAGOON = 229,680

TOTAL FLOW DISCHARGE TO LAGOON = 7,120,000

TOTAL DAYS IRRIGATED = 12

TOTAL GALLONS SPRAYED ON FIELD = 3,582,000

TOAL SPRAY VIOLATIONS = 0